

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI-110 001

No. F6/OFS/MS/school/2011/3330

Dated: 02/12/11

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Sr. Secondary School** at Shalimar Village, Delhi-110088 is comprised of ground & first floor only thus below 09 meters have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education & verified by the officer concerned of Fire Service on 24.09.2011 in the presence of Smt. Harbir Kaur Bindra (Vice -Principal), Govt. Girls Sr. Secondary School and that the building/premises is fit for occupancy Class B (**Educational**) with effect from 02/12/11 for a period of three years subject to the conditioned mentioned below.

Issued on ...02/12/11... at New Delhi by.



DIRECTOR

Delhi Fire Service

To:

Smt Harbir Kaur Bindra (Vice -Principal),
Govt. Girls Sr. Secondary School
Shalimar Village, New Delhi-88.

etc
A.S.O.
M

29/11

Copy to: -

The Director of Education,
Old Secretariat,
Delhi.

Following fire safety directives must be adhered to: -

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building Bye-Laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May kindly see the letter no.246 dated 15.06.2011 received from Smt Harbir Kaur Bindra (Vice Principal), Govt. Girls Sr. Sec. School at Shalimar village, Delhi-110088 regarding issuance of NOC from fire safety point of view. Premises was inspected by the ADO (WP) on 24.09.2011 & observed that the school building is comprised of ground & first floor only having plot area approx 6700 sq. mtrs. and covered area is 2280 sq. mtrs. approx.

The point wise compliance of fire safety recommendations accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education are given below -

INSPECTION REPORT				
1	Name & Address of the building	Govt. Girls Sr. Sec. School		
	Type of occupancy	Educational		
3	Type of case	New Case (old Building)		
4	Details of previous NOC	Nil		
5	Fire Safety directives letter no.	Nil		
6	Date of Inspection	24.09.2011		
7	Name of the Inspecting officers	Mr. Raj Mal Khokhar, ADO(WP)		
8	Name and designation of officers from the building	Smt. Harbir Kaur Bindra (Vice Principal)		
9	Year of Construction	Year 2005 (Old Building)		
10	Applicant's letter no.	246 dated 15.06.2011		
S.N	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 mtrs.	9 mtrs.	MR
	Gate width	5 mtrs.	5 mtrs.	MR
	Width of internal road	NR	NP	
2	Number, Width, type & Arrangement of Exits			
	a. Number of staircases			
	Upper Floors	2 nos.	Provided	MR
	Basement	NA	NA	
	a. Width of staircases			
	Upper Floors	1.3 mtrs and 1.2 mtrs.	Provided	MR
	Basements	NA	NA	
	b. Protection of exits			
	Fire check door	NR	NP	
	Pressurization	NR	NP	
	c. No. of continuous staircases to terrace	One	Provided	MR
	d. Width of Corridor	NR	NP	
	e. Door Size	1 mtr. width & 2 mtrs. in height in each room	Provided	MR
3	Compartmentation			
	• Fire check door	NR	NP	
	• Sealing of electrical shafts	NR	NP	
	• Fire Rating of shaft door	NR	NP	
	• Water curtain	NR	NP	
	• Fire Dampers	NR	NP	
4	Smoke Management System			
	• Basements	NR	NP	
	• Upper Floors	NR	NP	

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types 	9 Nos.	Provided	MR
		7 nos. ABC type cap. 5 kg		
		2 nos. WCo2 type cap. 9 ltrs	Provided	MR
	<ul style="list-style-type: none"> ISI marking 	Yes	Provided	MR
6	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers of each floor Length of hose reel hose Nozzle diameter 	Not Required	NP	
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main panel Location of repeater Panel Alternation source of power Hooter's location 	NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
8	MOEFA	NR	NP	
9	Public Address System	NR	NP	
10	Automatic Sprinkler System	Required	Provided	MR
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	
		NR	NP	
		NA	NA	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser down-come Number of hydrants per floor Hose Box 	NR	NP	
		-	-	
		-	-	
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR	NP	
		NR	NP	
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of Main pump Number of main pumps Jockey pump output Jockey Pump Head Standby Pump output Standby pump head Auto starting Manual stopping Pump House Access Terrace Level Discharge of the pump Head of the Pump Power Supply Auto Starting of Pump 	NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		Not Required	NP	
		-	-	
		-	-	
		-	-	
		-	-	
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire Service inlet Access to tank Overhead Tank capacity 	NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		Not Required	NP	
15	Exit Signage	Required	Provided	MR

16	Provision of Lifts			
	• Pressurization of Lift Shaft	NR	NP	
	• Pressurization of Lift Lobby	NR	NP	
	• Communication in lift car	NR	NP	
	• Fireman's Grounding Switch	NR	NP	
	• Lift Signage	NR	NP	
17	Standby Power Supply	NR	NP	
18	Refuge Area			
	• Total Area	NR	NP	
	• Location	NR	NP	
19	Fire Control Room			
	• Detector System Panel	NR	NP	
	• Flow Switch Panel	NR	NP	
	• P.A system Panel	NR	NP	
	• Batter backup	NR	NP	
	• Building Floor Plans	NR	NP	
20	Special Fire Protection Systems for Protection of special Risks, If any:	NA	NA	

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education.



Signature of the Inspecting officer

Signature of the Inspecting officer

Name RAJMAL SHUKHARIA

Name

Designation ACSH Div. officer

Designation