

★
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No. *FG (DFSS) M/S/School/2011/3361* Dated *05/12/2011*

FIRE SAFETY CERTIFICATE

Certified that the M.C.Primary School -I at Laxmi Nagar, Delhi. Comprised of ground floor only owned/ occupied by M/S M.C.Primary School have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dtd.01.03.2011 and verified by the officer concerned of fire service on 11.11.2011 in the presence of Smt. Santosh Kumari, Principal, of the school and that the building is fit for occupancy, class B "Educational Building" with effect from - 12-2011 for a period of three years, subject to conditions printed overleaf.

Issued on

at New Delhi.



Chief Fire Officer
Delhi Fire Service

9c
5/12/11

Copy to:-

1. The Principal
M.C.Primary School -I
Laxmi Nagar, Delhi - 92
2. The Director Education,
MCD, Nigam Bhawan,
Kashmiri Gate, Delhi.
3. The Principal
M.C.Primary School -II
Laxmi Nagar, Delhi - 92

Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M. C. Psy. School (I & II), Laxmi Ngs. Delhi.
2. Type of Occupancy : Educational.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 11. 11. 11.
7. Name of the Inspecting Officers : Gurmnkh Singh
8. Name and designation of officers from the building side : Principal (Santosh Kumari)
9. Year of Construction : 1962 (as appraised)
10. Applicant's letter No. : -N12- alt-3/11/11

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>07 mtr</u>	<u>10/12</u>
	• Gate width	<u>—</u>	<u>—</u>	
	• Width of internal road	<u>—</u>		
2	Number, Width, Type & Arrangement of Exits	<u>NA</u>		
	a. Number of staircases	<u>NA</u>	<u>NA</u>	
	• Upper Floors	/	/	
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size			

3	Compartmentation.	NA	NA	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	/	/	
4	Smoke Management System.	NA	NA	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	/	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	2 Nos. ABC & CO ₂ ISI marked	04 Nos ✓ ABC & CO ₂ YES	100R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA 30 m 5 mm	NA /	
7	Automatic fire detection and alarming system.	NA	NA	
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	/	/	
8	MOEFA	NA	NA	
9	Public Address System.	NA	NA	
10	Automatic Sprinkler System.	NA	NA	
	<ul style="list-style-type: none"> • Basement 	/	/	

	<ul style="list-style-type: none">• Upper Floor• Sprinkler above false ceiling	/	/	
11	Internal Hydrants	NA	NA	
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box	/	/	
12	Yard Hydrants.	NA	NA	
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box	/	/	
13	Pumping Arrangements.	NA	NA	
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump	/	/	
14	Captive Water Storage for fire fighting.	NA	NA	
	<ul style="list-style-type: none">• Underground tank capacity➤ Draw-off connection	/	/	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	/	/	
15	Exit Signage.	NA	NA	
16	Provision of Lifts.	NA	NA	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	/	/	
17	Standby power supply	NA	NA	
18	Refuge Area.	NA	NA	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	/	/	
19	Fire Control Room	NA	NA	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	/	/	
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	

The fire protection systems provided in the building were test checked and found functional at the of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~

14/11/11
14/11/11

Signature of the Inspecting Officer

Name Gurmukh Singh

Designation ADO (LH)

Signature of the Inspecting Officer

Name

Designation