

INSPECTION REPORT

1. Name & address of the building:- Mohyal Public School at Sector-3, R. K. Puzam, New Delhi - 110022.
2. Type of occupancy:- Education Building
3. Type of case:- New
4. Details of previous NOC:- New
5. Fire safety directives No.- NA
6. Date of inspection:- 13-09-11
7. Name of the inspecting officer:- A.D.O. S. S. Kaushik
8. Name & designation of officer From the building side:- Mr K C Chhibber
9. Year of construction:- 1990-91
10. Applicant's letter No:- NIL Dated 19/08/2011 *Ground floor only*

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Approachable	Yes	MR
	2) Gate width	Required	Yes	MR
	3) Width of internal road			
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases	NA	NA	NA
	1. Upper floors	NA	NA	NA
	2. Basements	NA	NA	NA
	B. Width of staircase	NA	NA	NA
	1. Upper floors	NA	NA	NA
	2. Basements	NA	NA	NA
	C. Protection of exits	NA	NA	NA
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	NA	NA	NA
	E. Width of corridor	NA	NA	NA
	F. Door size	Required	Emergency Provided	MR
3.	Compartmentation			
	1) Fire check door	NA	NA	NA
	2) Sealing of electrical shafts	/	/	/
	3) Fire rating of shaft door	/	/	/
	4) Water curtain	/	/	/
	5) Fire Dampers	/	/	/
4.	Smoke Management System			
	1) Basements	30 a/c per hour	NA	NA
	2) Upper floors	12 a/c per hour	/	/
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	9 Not provided	MR
	2) Types		ABC types	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor		NA	NA
	2) Length of hose reel hose	30 m	/	/
	3) Nozzle diameter	5 mm	/	/
7.	Automatic Fire Detection & Alarming System			

	1) Type of detectors	NA	NA	NA
	2) Location of main panel	/	/	/
	3) Location of repeater panel	/	/	/
	4) Alternate source of power	/	/	/
	5) Hooter's Location	/	/	/
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
	1) Basement	/	/	/
	2) Upper floors	/	/	/
	3) Sprinkler above false ceiling	/	/	/
11.	Internal Hydrants	NA	NA	NA
	1) Size of riser/down-comer	/	/	/
	2) Number of hydrants per floor	/	/	/
	3) Hose box	/	/	/
12.	Yard Hydrants	/	/	/
	1) Total number of hydrants	/	/	/
	2) Hose box	/	/	/
13.	Pumping Arrangement	NA	NA	NA
	1) Ground level	/	/	/
	a) Discharge of main pump	/	/	/
	b) Head of main pump	/	/	/
	c) Number of main pump	/	/	/
	d) Jockey pump output	/	/	/
	e) Jockey pump head	/	/	/
	f) Stand by pump output	/	/	/
	g) Stand by pump head	/	/	/
	h) Auto starting/Manual stopping	/	/	/
	2) Terrace level	/	/	/
	a) Discharge of pump	/	/	/
	b) Head of pump	/	/	/
	c) Power supply	/	/	/
	d) Auto starting of pump	/	/	/
14.	Captive Water Storage for Fire Fighting	/	/	/
	1) Under ground tank capacity	NA	NA	NA
	a) Draw-off connection	/	/	/
	b) Fire service inlet	/	/	/
	c) Access to tank	/	/	/
	d) Over head tank capacity	/	/	/
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.	NA	NA	NA
	a) Pressurization of lift shaft	/	/	/
	b) Pressurization of lift lobby	/	/	/
	c) Communication in lift car	/	/	/
	d) Fireman's switch	/	/	/
	e) Lift signage	/	/	/
17.	Stand by Power Supply	NA	NA	NA
18.	Refuge Area	/	/	/
	Total area location	NA	NA	NA

19.	Fire Control Room	MA	MA	MA
	a) Detector system panel			
	b) Flow switch panel			
	c) PA system panel			
	d) Battery backup			
	e) Building floor plan			

20. Special Fire Protection System for Protection of special Risk, if any:

owner has given an affidavit stating that safety cap of each classroom is less than 40
 The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers-----

Signature of the inspecting officer	Signature of the inspecting officer 
Name	Name S. S. Kausik
Designation	Designation Asstt. Div. Officer

NO. F6/DF S/2013/school/2011/3147

DATED: 24/11/11

FIRE SAFETY CERTIFICATE

Certified that the M/s Mohyal Public School located at Sector -3, R.K. Puram, New Delhi-110057 comprise of only ground floor owned/occupied by M/s Mohyal Education Society. The inspection of school was carried out & found complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire/Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 13.09.2011 in the presence of Mr. K.C. Chhibber, of the school and that the building is fit for occupancy class B "Educational building" with effect from 24/11/11.... for a period of **three** years subject to condition as mentioned below.

Issued on ...24/11/11..... at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to,

1. The Director, Education, G. N.C.T Delhi, Old Secretariat, Delhi
2. The Principal, Mohyal Public School building at Sector-3, R.K.Puram, New Delhi-110022.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in