

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/school/2011/3331 Dated: 02/12/2011

FIRE SAFETY CERTIFICATE

Certified that the Rajkiya Pratibha Vikas Vidyalaya, is comprised of Ground + 01 upper floor building thus below 09 mtrs, located at A-6, Paschim Vihar, New Delhi 110063 have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 13/09/2011 in the presence of Principal Archam Vishwadeep and that the building premises is fit for occupancy of Group B Educational Building Class Sub Div. B-1 (Schools upto Senior Secondary level) with effect from 02/12/2011 for a period of three years, subject to conditions mentioned below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangements, means of escape facilities shall be maintained in good working condition at all times. Any lapse rendering fire safety systems or means of escape facilities non-functional shall be responsibility of the management.
2. Building sanctioning authority may verify any deviation with regard to the construction occupancy in the building. In case of any deviation, the fire safety certificate shall be null and void.
3. The staff shall be trained for operating fire fighting systems and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available at WWW.dfs.Delhigovt.nic.in

Issued on 02/12/11 at New Delhi by

  
Chief Fire Officer  
For Director  
Delhi Fire Service

Copy to:

1. The Principal, Rajkiya Pratibha Vikas Vidyalaya, A-6, Paschim Vihar, New Delhi 110063
2. The Director of Education, Old Secretariat, Delhi

*gca*

INSPECTION REPORT

1. Name & address of the building : Rajniya Pratibha Vikas Vidyalaya, A-6,  
Paschim Vihar, ND-63
2. Type of Occupancy : School (G+1)
3. Type of Case :  New Case       Renewal
4. Details of previous NOC : Letter No. \_\_\_\_\_ Dated: \_\_\_\_\_
5. Fire Safety directives letter No. : ~~ADD~~ Pw Dir of Edu LRO dtd 1/3/11
6. Date of inspection : 13/9/11
7. Name of the Inspecting Officers : S.S. Tuli ADDO (M.N)
8. Name and designation of officers  
from the building side : Smt Archana Vishwadeep (Principal)
9. Year of Construction : —
10. Applicant's letter No. : PVV/PV/A6/958 dtd 20/5/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement <i>Dir of Edu dtd 1/3/11</i>	Provided at site	Remarks M/R/NDR
1	Access to building			
	• Road width	6 mtr	6 mtr	— MR
	• Gate width	4.5 m	5 mtr	— " —
	• Width of internal road	—	4 mtr	— " —
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		04	—
	• Upper floors		04	—
	• Basements		—	—

b. Width of staircases	1.5M & .75M ←————→	140CM X 3 MS X 1 MS	MR
• Upper Floors	- do	- do	MR
• Basements	-	-	-
c. Protection of exits	-	-	-
• Fire check door	-	-	-
• Pressurization	-	-	-
e. No. of continuous staircases to terrace	-	-	-
g. Width of Corridor	1.50M	150CM	1 MTR
h. Door Size	1 MTR	1 MTR	1 MTR
3. Compartmentation.	NR	NP	NP
• Fire check door	-	-	-
• Sealing of electrical shafts	-	-	-
• Fire Rating of shaft door	-	-	-
• Water Curtain	-	-	-
• Fire Dampers	-	-	-

4	Smoke Management System.	NR	NP	NA
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers		08	NR
	• Types	ISI marked	ABC	NR
	• IS marking		ISI	NR
6	First-Aid Hose Reels.	NR	NP	NA
	• Total numbers on each floor		—	—
	• Length of hose reel hose	30 m	—	—
	• Nozzle diameter	5 mm	—	—
7	Automatic fire detection and alarming system.	NR	NP	NA
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MIOFFA	NR	NP	NA
9	Public Address System.	— " —	Provided	NR

10	Automatic Sprinkler System.	NR	NP	NA
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants	NR	NP	NA
	• Size of riser down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—
12	Yard Hydrants.	NR	NP	NA
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.	NR	NP	NA
	• Ground Level	—	—	—
	• Discharge of main Pump	—	—	—
	• Head of Main pump	—	—	—
	• Number of main pumps	—	—	—
	• Jockey Pump out put	—	—	—
	• Jockey pump head	—	—	—
	• Standby Pump out put	—	—	—
	• Standby Pump Head	—	—	—

➤ Auto Starting Manual stopping	NR	NP	NA
➤ Pump House Access	-	-	-
terrace level	-	-	-
➤ Discharge of pump	-	-	-
➤ Head of the pump	-	-	-
➤ Power Supply	-	-	-
➤ Auto Starting of pump	-	-	-

14 Captive Water Storage for fire fighting.

• Underground tank capacity	NR	NP	NA
➤ Draw-off connection	-	-	-
➤ Fire service inlet	-	-	-
➤ Access to tank	-	-	-
• Overhead tank capacity	-	-	-



15	Exit Signage.	NR	NP	NA
16	Provision of Lifts.	NR	NP	NA
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In Lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	Standby power supply	-	-	-
18	Refuge Area.	NR	NP	NA
	• Total Area	-	-	-
	• Location	-	-	-
19	Fire Control Room	NR	NP	NA
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010. Issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

  
S.S. Tullu

Designation

A.D.O.

Signature of the Inspecting Officer

Name

Designation