

No : F.6/DFS/MS/2011/ school/3175

Dated : 25/11/11

To

The Vice Principal,
Salwan Boys Sr. Sec. School,
Old Rajinder Nagar,
New Delhi-110060.

RefNo : No.SBS/107/2011 dated 23.09.2011.

FIRE SAFETY CERTIFICATE

Certified that the - Salwan Boys Sr. Sec. School, Old Rajinder Nagar, New Delhi-110005 comprised of - ground floor plus one upper floors, owned/occupied by Salwan Boys Sr. Sec. School has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire Service on 08.11.2011 in the presence of - Smt. Sharmstha Gupta (vice principal) and that the building/premises is fit for occupancy class - group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on25/11/11.....at New Delhi

Copy to :

1. The Director
Govt. of N.C.T. of Delhi
Directorate of Education,
Old Secretariat, Delhi


Chief Fire Officer
Delhi Fire Service.



INSPECTION REPORT

1. Name & address of the building : Salwan Boys Sr. Sec. School, Old Rajender Nagar N.D.
 2. Type of Occupancy : Educational
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. NIL Dated: NIL
 5. Fire Safety directives letter No : NIL
 6. Date of inspection : 08.11.2011
 7. Name of the Inspecting Officers : D.O. H.L. Anjeja
 8. Name and designation of officers from the building side : Mrs. Sharmista Gupta (Principal.)
Mr. Baldev Singh Lab. Assistant.
 9. Year of Construction :
 10. Applicant's letter No. : SBS/107/2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R.	6mtrs	M.R.
	• Gate width	R.	3.70mtrs	MR.
	• Width of internal road	R	9 mtrs	M.R.
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	2 Nos	M.R.
	• Upper Floors	R	2 Nos	— —
	• Basements	NIL	NIL	NIL
	b. Width of staircases	R.	150cms L 140cms	M.R.
	• Upper Floors	— —	— —	— —
	• Basements	NIL	NIL	NIL
	c. Protection of exits	NR	NP	MHR
	• Fire check door	— —	— —	— —
	• Pressurization	— —	— —	— —
	e. No. of continuous staircases to terrace	— —	— —	— —
	g. Width of Corridor	R	1 No	MR
	h. Door Size	R	240cms	MR.
		R	104 X 203cm	M.R.

3	Compartmentation.	NR	NP	NMR
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	/	/	/
4	Smoke Management System.	NR	N.P	NMR
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	/	/
5	Fire Extinguishers	R.	Provided.	NR
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	R. ISI marked	IS Nos ABC types Yes	NR NR NR
6	First-Aid Hose Reels.	NR	NP	NMR
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	/	/
7	Automatic fire detection and alarming system.	NR	N.P.	NMR
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	/	/	/
8	MOEFA	NR	N.P	NMR
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.	NR	N.P	NMR
	<ul style="list-style-type: none"> • Basement 	—	—	—

	<ul style="list-style-type: none">• Upper Floor• Sprinkler above false ceiling	/	/	/
11	Internal Hydrants	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box	/	/	/
12	Yard Hydrants.	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box	/	/	/
13	Pumping Arrangements.	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump	/	/	/
14	Captive Water Storage for fire fighting.	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none">• Underground tank capacity➤ Draw-off connection	/	/	/

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	/	/	/
15	Exit Signage.	N.R.	N.P.	NMR.
16	Provision of Lifts.	N.R.	N.P.	N.MR.
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	/	/	/
17	Standby power supply	N.R.	N.P.	NMR
18	Refuge Area.	N.R.	N.P.	NMR
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	/	/	/
19	Fire Control Room	N.R.	N.P.	NMR
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	/	/	/
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.P.	NMR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~ NIL

[Handwritten Signature]

Signature of the Inspecting Officer

Name H. L. ANEJA

Designation Div. Officer

Signature of the Inspecting Officer

Name

Designation

[Handwritten mark]