

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No: FC/DF3/MS/2011/school/3581

Dated: 16/12/2011

FIRE SAFETY CERTIFICATE

Certified that the building of **Govt. Boys. Sr. Sec. School**, Jharoda Kalan, New Delhi -110072 comprising of Ground Floor plus one Upper Floor and having total 20 rooms (Including Class Rooms, Science Lab, Sports Room, Staff Room, Computer Lab, Library & Office etc) owned/occupied by The Govt. of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education, Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 05.11.2011 in the presence of Sh. Virender Singh and that the building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 16/12/11 at New Delhi

CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE

of
Mun

Copy to:-

- 1 Sh. S. S. Parihar
Joint Director Of Education (Land & Estate)
Lucknow Road, New Delhi-110054.
(Ref No- PA/JDE (L&E)/2010-11/5791 dated 08.09.11)
- 2 The Vice Principal,
Govt. Boys. Sr. Sec. School,
Jharoda Kalan, New Delhi-110072.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

May kindly see the letter no. PA/JDE(L&E)/2010-11/5791 dated 08-09-11, received from Mr. S.S. Parihar, Joint Director of Education (Land & Estate), Lucknow Road, New Delhi – 54,. Regarding grant of fire safety certificate in respect of Govt. Boys Sr. Sec. School, Jharoda Kalan, New Delhi – 110072.

In this connection it is stated that the school building in question was inspected by under signed on 05/11/11 with a view to ensure the compliance of the fire safety recommendation issued from the Director of education vide circular no.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 Mr. Virender Singh was also present.

During the course of inspection it was observed that the school building is comprised of ground plus one upper floor. The upper floor is served by two staircases having width 150 cm each. The building is directly approachable to the fire fighting vehicles. The electrical wiring was seen concealed and the electric supply was passing through MCB's. The building is properly ventilated. The room allocation in the school is as under:-

Ground plus First floor Total 20 Rooms (including class rooms Sci. Lab, Sports Room, Staff Room, Comp. Lab, Library and Office etc.

The school building is protected by the following fire safety arrangements are as under:-

- | | | |
|-------------------------------------|---|--|
| 1. Access to the building | - | Available |
| 2. Numbers of Doors in a Class Room | - | Classes with more than 45 students are having double doors |
| 3. Staircase | - | 02 staircases of 150cm width each. |
| 4. Fire Extinguisher | - | CO ₂ type fire extinguisher of 2.5 Kg. cap. And ABC type fire extinguisher of 5 Kg. Capacity are provided in the building as per above said circular. |

The Fire Extinguishers were checked and the performance found satisfactory at the time of inspection. In view of the above the school premises may be considered safe from Fire Safety point of view for grant of Fire Safety Certificate for running the school in above said building.

DFA is put-up accordingly for your perusal and signature please.

D.O (S.W)

(Signature)
16/11/11