

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No F6/DRS/MS/school/2011/3372 Dated 05/12/11

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys Sr. Sec. School, East Gokal Pur, Loni Road, Delhi. Comprised of ground & first floor with 43 rooms have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education GNCTD and verified by the officer concerned of this department on 22-11-2011 in the presence of the Principal, and that the building is fit for occupancy, class B "Educational Building" with effect from 5-12-2011 for a period of three years, subject to conditions printed overleaf.

Issued on 05/12/11 at New Delhi.



Chief Fire Officer

Delhi Fire Service

OC
Real
3/12/11

Copy to:-

1. The Principal
Govt. Girls Sr. Sec. School
East Gokal Pur, Loni Road,
Delhi 110094
2. The Director Education,
Government of N.C.T Delhi.
Old Sectt, Delhi 110054
3. Govt. Boys Sr. Sec. School
East Gokal Pur, Loni Road,
Delhi 110094

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No *F6/DRS/MS/school/2011/3372* Dated *05/12/11*

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys Sr. Sec. School, East Gokal Pur, Loni Road, Delhi. Comprised of ground & first floor with 43 rooms have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education GNCTD and verified by the officer concerned of this department on 22-11-2011 in the presence of the Principal, and that the building is fit for occupancy, class B "Educational Building" with effect from *5-12*-2011 for a period of three years, subject to conditions printed overleaf.

Issued on *05/12/11* at New Delhi.



Chief Fire Officer
Delhi Fire Service

QC
Real
3/12/11

Copy to:-

1. The Principal
Govt. Girls Sr. Sec. School
East Gokal Pur, Loni Road,
Delhi 110094
2. The Director Education,
Government of N.C.T Delhi.
Old Sectt, Delhi 110054
3. Govt. Boys Sr. Sec. School
East Gokal Pur, Loni Road,
Delhi 110094

Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt. Boys/Girls Sr. Sec. School East Gokulpur,
2. Type of Occupancy : 'B' Educational. Loni Road, Delhi - 94
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 22.11.11
7. Name of the Inspecting Officers : Guramkh Singh
8. Name and designation of officers from the building side : Sh. Brahm Pal, Principal
9. Year of Construction : 2005
10. Applicant's letter No. : 177 dt 21.6.11 (Copy)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	
	• Gate width	— " —	— " —	
	• Width of internal road	NA	NA	
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2 Nos.	2 Nos. each blk.	
	• Upper Floors	2 Nos.	2 Nos. each block	
	• Basements	NA	NA	1 more staircase under const.
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.47, 1.38, 1.32 & 1.38 mtr	
	• Basements	NA	NA	
	c. Protection of exits			
	• Fire check door	NA	NA	
	• Pressurization	/	/	
	e. No. of continuous staircases to terrace	/	/	
	g. Width of Corridor	1.5 mtr	1.4 mtr	
	h. Door Size	1.0 mtr	1.0 mtr	

EA - 2012 - 002600

3	Compartmentation.	N.A.	N.A.	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	/	/	
4	Smoke Management System.	N.A.	N.A.	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	/	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	11 Nos. ABC & CO ₂ Type ISI marked	13 Nos. ABC & CO ₂ Type YES ISI	m/R
6	First-Aid Hose Reels.	N.A.	N.A.	
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	N.A. N.A. N.A.	
7	Automatic fire detection and alarming system.	N.A.	N.A.	
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	/	/	
8	MOEFA	N.A.	N.A.	
9	Public Address System.	N.A.	Provided.	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N.A.	N.A.	

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	N.A.	N.A.	
		N.A.	N.A.	
11	Internal Hydrants	N.A.	N.A.	
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	/	/	
12	Yard Hydrants.	N.A.	N.A.	
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	/	/	
13	Pumping Arrangements.	N.A.	N.A.	
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	/	/	
14	Captive Water Storage for fire fighting.	N.A.	N.A.	
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	/	/	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	
15	Exit Signage.	NA	NA	
16	Provision of Lifts.	NA	NA	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	/	/	
17	Standby power supply	NA	NA	
18	Refuge Area.	NA	NA	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	/	/	
19	Fire Control Room	NA	NA	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	/	/	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under *Circular of Director Education* / issue shortcomings as noted at serial numbers.....

Asstt. Div. Officer
23/11/17

Signature of the Inspecting Officer

Name *Gurmukh Singh*

Designation *Asstt. Div. Officer*

Signature of the Inspecting Office

Name

Designation