GOVERNTMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI-110001

No:

F6/DF3/Ms/schne/201/3566

Dated:

16/12/1

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. Boys. Sr. Sec. School No-2, Uttam Nagar, New Delhi -110059 comprising of Ground Floor only and having total 33 rooms (Including Class Rooms, Science Lab, Computer Lab, Sports Room, Staff Room, Drawing Room, Office, & Examination Room etc) owned/occupied by Directorate of Education, Govt. of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education, Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 05.11.2011 in the presence of Mr. Parmod Kumar and that the building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE

Copy to:

- Dr. D. S. Kumar (Principal)
 Govt. Boys. Sr. Sec. School No-2,
 Uttam Nagar, New Delhi-110059.
 (Ref No-GBSSS No-2/UN/2011/429, dated 18.10.11)
- 2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110 054.

Following fire safety directives must be adhered to –

- 1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
- 3. The trained staff should be available round the clock.
- 4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

May kindly see the letter no. GBSSSNO.2/UN/2011/429, dated 18-10-11, received from the Principal, Govt. Boys Sr. Secondary School No. 2, Uttam Nagar, New Delhi - 110059. Regarding grant of fire safety certificate in respect of above said school.

In this connection it is stated that the school building in question was inspected by under singed on 05/11/11 with a view to ensure the compliance of the fire safety recommendation issued from the Director of education vide circular no.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 Sh. Parmod was also present.

During the course of inspection it was observed that the school building is comprised of ground floor only. The building is directly approachable to the fire fighting vehicles, the electrical wiring was seen concealed and the electric supply was passing through MCB's. The building is properly ventilated. The room's allocation in the school is as under:-

Ground floor _ Total 33 .Class Rooms (including class rooms, Science Lab, Computer Lab, Sports Room, Staff Room, Drawing Room, Office and Examination Room etc.)

The school building is protected by the following fire safety arrangements are as under:-

1. Access to the building - Available

2. Numbers of Doors in a Class Room - Classes with more than 45 students are having double doors

3. Fire Extinguisher

Co₂ type fire extinguisher of 2.5
Kg. cap. And ABC type fire extinguisher of 5 Kg. Capacity, are provided in the building as per above said circular.

The Fire Extinguishers were checked and the performance found satisfactory at the time of inspection. In view of the above the school premises may be considered safe from Fire Safety point of view for grant of Fire Safety Certificate for running the school in above said building.

DFA is put-up accordingly for your perusal and signature please.

D.O (S.W)

Submitted please,