

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


No: F6/DAS/ms/School/2011/3553

Dated: 16/12/11

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. Co-Ed. Secondary School, Baprola Vihar, New Delhi -110043 comprising of Ground Floor plus one upper floor, having total 20 rooms (Including Class Rooms, Science Lab, Computer Lab, Staff Room, Examination Room & Office etc) owned/occupied by The Govt of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education, Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 01.12.2011 in the presence of School Vice Principal Smt. Mary Minz and that the building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 16/12/11.....at New Delhi



CHIEF FIRE OFFICER  
For DIRECTOR  
DELHI FIRE SERVICE

o/c  
MLW

Copy to:

- 1 The Vice Principle,  
Govt. Co-Ed. Secondary School,  
Baprola Vihar, New Delhi-110043.  
(Ref No- 231, dated 21.09.11)
- 2 Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/1.

May kindly see the letter No. 231 dated 21.09.2011 received from the Vice Principal, Govt. Co-Ed. Secondary School, Baprola Vihar, New Delhi-110043, regarding grant of fire safety certificate in respect of above said school.

In this connection it is stated that the school building in question was inspected by undersigned on 01.12.2011 with a view to ensure the compliance of the fire safety recommendations issued by the Director of education vide circular No.F.16/Estate/CC/Fire.Safety/2011/3298 to 3398 dated 01-03-2011. School Vice Principal Smt. Mary Minz was also present.

During the course of inspection it was observed that the school building is comprised of ground floor plus one upper floor. The upper floor is served by two staircases having width 147 cms each. The building is directly approachable to the fire fighting vehicles. The electrical wiring was seen concealed and the electric supply was passing through MCB's. The building is properly ventilated. The room's allocation in the school is as under: -

**Total Rooms:** - 20 Rooms (Including Class Rooms, Science Lab, Computer Lab, Staff Room, Examination Room & Office etc.)

The school building is protected by the following fire safety arrangements are as under: -

1. **Access to the building:** Available.
2. **Numbers of Doors in a Class Room:** Double doors are provided.
3. **Fire Extinguishers:** One Co2 type Fire Extinguisher of 2.5 Kgs Cap. With ISI Marked or one ABC type Fire Extinguisher with ISI marked for every 300 sq.m of covered area, In addition, one Fire Extinguisher each in Laboratory, near to the electrical installation and /or generator Room are provided in the building as per the above said circular.
4. **Staircase:** - Provided two staircases having width 147 cms each.

The Fire Extinguishers were checked and the performance found satisfactory at the time of inspection. In view of above said school premises may be considered safe from fire safety point of view for grant of fire safety certificate for running the school in above said building.

DFA is put up accordingly for your perusal and signature please.

D.O (S.W)

*[Signature]*  
2/12/11

*Submitted please*  
*[Signature]*  
5/12/11