GOVERNTMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI-110001

No:

F6 (253) MS | School /2011/3596

Dated:

16/12/201)

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. Co-Ed. Sr. Sec. School, Mitraon, New Delhi-110043 comprising of Ground Floor only and there are five blocks. Having total 28 rooms (Including Class Rooms, Sports Room, Staff Room, Examination Room, Science Lab, Computer Lab, Library, Math Lab & Office etc) owned/occupied by The Govt of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education, Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 19.11.2011 in the presence of School Vice Principal Sh. Munshi Lal and that the building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE

Copy to: -

- The Vice Principle, Govt. Co-Ed. Sr. Sec. School, Mitraon, New Delhi-110043. (Ref No-720, dated 13.09.11)
- 2 Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.

Following fire safety directives must be adhered to –

- 1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
- 3. The trained staff should be available round the clock.
- 4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

May kindly see the letter No. 720 dated 13.09.2011 received from the Vice Principal, Govt. Co-Ed. Sr. Sec. School, Mitraon, New Delhi-110043, regarding grant of fire safety certificate in respect of above said school.

In this connection it is stated that the school building in question was inspected by undersigned on 19.11.2011 with a view to ensure the compliance of the fire safety recommendations issued from the director of education vide circular No.F.16/Estate/CC/Fire.Safety/2011/3298 to 3398 dated 01-03-2011. School Vice Principal Sh. Munshi Lal was also present.

During the course of inspection it was observed that the school building is comprised of ground floor only and there are five blocks. The building is directly approachable to the fire fighting vehicles. The electrical wiring was seen concealed and the electric supply was passing through MCB's. The building is properly ventilated. The room's allocation in the school is as under: -

Ground Floor: - Total 28 rooms (Including Class Rooms, Sports Room, Staff Room, Examination Room, Sci. Lab, Comp. Lab, Library, Math Lab & Office etc.)

The school building is protected by the following fire safety arrangements are as under: -

- 1. Access to the building: Available.
- 2. Numbers of Doors in a Class Room: Double doors are provided.
- 3. **Fire Extinguishers:** One Co2 type Fire Extinguisher of 2.5 Kgs Cap. With ISI Marked or one ABC type Fire Extinguisher with ISI marked for every 300 sq.m of covered area, In addition, one Fire Extinguisher each in Laboratory, near to the electrical installation and /or generator Room are provided in the building as per the above said circular.

The Fire Extinguishers were checked and the performance found satisfactory at the time of inspection. In view of above said school premises may be considered safe from fire safety point of view for grant of fire safety certificate for running the school in above said building.

DFA is put up accordingly for your perusal and signature please.

D.O (S.W)

100 lya 21 11/11