

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No : F.6/DFS/MS/2011/ *school/3486*

Dated : *14/12/11*

To


The Principal,  
Kendriya Vidyalaya,  
C-2, Area, Janak Puri,  
New Delhi-110058.

Ref No : No.49/KVJP/2011-12/1115 dated 13.07.2011.

FIRE SAFETY CERTIFICATE

Certified that the - Kendriya Vidyalaya, C-2, Area, Janak Puri, New Delhi-110058. Comprised of - ground floor plus one upper floors, owned/occupied by Kendriya Vidyalaya, C-2, Area, Janak Puri, New Delhi-110058. has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire Service on 14.11.2011 in the presence of - Sh. A.K. Guatam (Principal) and that the building/premises is fit for occupancy class - group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the De hi Fire Service Rules,2010 printed overleaf.

Issued on .....*14/12/11*.....at New

  
Chief Fire Officer  
For Director  
Delhi Fire Service

*o/c*  
*Man*

**INSPECTION REPORT**

1. Name & address of the building : Kendriya Vidyalaya, C-2 Area, Janak Puri  
Delhi - New Delhi
2. Type of Occupancy : \_\_\_\_\_
3. Type of Case :  New Case/~~Renewal~~
4. Details of previous NOC : Letter No. NIC Dated: \_\_\_\_\_
5. Fire Safety directives letter No : NIC
6. Date of inspection : 14.11.2011
7. Name of the Inspecting Officers : D.O. H.C. Anuja
8. Name and designation of officers from the building side : Sh. A.K. Guatam, Principal
9. Year of Construction : 1979
10. Applicant's letter No. : 49/KVSP/2011-12/1115 dt 13.7.2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	R	12 mtrs	MR
	• Gate width	R	360 mtr	MR
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	R	four No	MR
	• Upper Floors	Nil	—	—
	• Basements	Nil	Nil	Nil
	b. Width of staircases	R	150, 150, 120, 125	MR
	• Upper Floors	—	—	MR
	• Basements	Nil	Nil	Nil
	c. Protection of exits	MR	MR	MR
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	R	4ft 6in	MR
	h. Door Size	R	1' 80 mtrs	MR
		R	1-00 mt	MR

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N.R.	N.R. N.P.	
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N.R.	N.P.	
		30 a/c per hour		
		12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	ISI marked	Provided R No / ABC type Yes	M/R M/R M/R M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	N.R.	N.P.	
		30 m		
		5 mm		
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	N.R.	N.P.	
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	N.R.	N.P.	
		M/R	M/R	N/R

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	—	—	—
11	<b>Internal Hydrants</b>	NR	NP.	—
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	—	—	—
12	<b>Yard Hydrants.</b>	NR	NP.	—
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	—	—	—
13	<b>Pumping Arrangements.</b>	NR	N.P	—
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	—	—	—
14	<b>Captive Water Storage for fire fighting.</b>	NR	NP.	—
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>	—	—	—

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
15	<b>Exit Signage.</b>	N.R.	N.P.	—
16	<b>Provision of Lifts.</b>	M.R.	N.P.	—
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	—
17	<b>Standby power supply</b>	N.R.	N.P.	—
18	<b>Refuge Area.</b>	M.R.	N.P.	—
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
19	<b>Fire Control Room</b>	M.R.	N.P.	—
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... Nil

Signature of the Inspecting Officer  
*[Handwritten Signature]*

Name *H. L. ANEJA*

Designation *Dir. Officer*

Signature of the Inspecting Officer

Name *[Handwritten Signature]*

Designation