

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. *FG/DFS/MS/School/2011/3569*

Dated: *16/12/2011*

FIRE SAFETY CERTIFICATE

Certified that the building of **Maharishi Vidhya Mandir Public School** located at A1/181, Madhu Vihar, Uttam Nagar, New Delhi-110059 comprised of Ground Floor plus one upper floor, having total 12 rooms (Including Class Rooms, Office & Store Room etc). Above school was issued NOC vide this office letter No.F.6/MS/DFS/2006/2382 dated 08.09.2007 owned/ occupied by Management of above said School have complied with the fire prevention and fire safety requirements in accordance by the Director of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officers concerned of fire service on 02.12.2011 in the presence of School Principal Sh. Vijay Kumar and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on..... at New Delhi.

[Signature]
16/12

CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE

o/c
Mer

Copy to: -

1. The President,
Maharishi Vidhya Mandir Public School,
A1/181, Madhu Vihar, Uttam Nagar,
New Delhi-110059.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110 054

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/3

May kindly see the letter No. Nil dated 08.09.2011 received from the President, Maharishi Vidhya Mandir Public School, A1/181, Madhu Vihar, Uttam Nagar, New Delhi-110059, regarding renewal of fire safety certificate in respect of above said school.

In this connection it is stated that the school building in question was inspected by undersigned on 02.12.2011 with a view to ensure the compliance of the fire safety recommendations issued from the director of education vide circular No.F.16/Estate/CC/Fire.Safety/2011/3298 to 3398 dated 01-03-2011. School Principal Sh. Vijay Kumar was also present.

During the course of inspection it was observed that the school building is comprised of ground floor plus one upper floor. The upper floor is served by two staircases having width 138 cms & 70 cms respectively. The building is directly approachable to the fire fighting vehicles. The electrical wiring was seen concealed and the electric supply was passing through MCB's. The building is properly ventilated. The School premises was issued NOC vide this department letter No. F.6/MS/DFS/2006/2382, dated 08.09.2006. The room's allocation in the school is as under:-

Total Rooms:- 12 Rooms (Including Class Rooms, Office & Store Room etc.)

The school building is protected by the following fire safety arrangements are as under: -

1. **Access to the building:** Available.
2. **Numbers of Doors in a Class Room:** Single door is provided. (Students less than 45 in each class.)
3. **Fire Extinguishers:** One Co2 type Fire Extinguisher of 2.5 Kgs Cap. With ISI Marked or one ABC type Fire Extinguisher with ISI marked for every 300 sq.m of covered area, In addition, one Fire Extinguisher each in Laboratory, near to the electrical installation and /or generator Room are provided in the building as per the above said circular.
4. **Staircase:** - Provided two staircases having width 138 cms & 70 cms respectively.
5. **First Aid Hose Reels:-** Provided at each floor with proper boosting arrangement.
6. **Over Head Tank:-** 2500 ltr cap. is provided.

The Fire Extinguishers/System were checked/operated and the performance found satisfactory at the time of inspection. In view of above said school premises may be considered safe from fire safety point of view for renewal of fire safety certificate for running the school in above said building.

DFA is put up accordingly for your perusal and signature please.

D.O(S.W)
f

1
05/12/11

Submitted phase
05/12/11

0