

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No : F.6/DFS/MS/2011/ *school/3493*

Dated : *14/12/11*

To


The Principal,
M.C. Primary Bal/Balika Adrash Vidyalaya,
C-2 Janak Puri
New Delhi-110058.

Ref No: No. Nil dated 10.10.2011.

FIRE SAFETY CERTIFICATE

Certified that the -M.C. Primary Bal/Balika Adrash Vidyalaya, C-2, Janak Puri, New Delhi-110018. Comprised of - ground floor plus one upper floor only, owned/occupied by M.C. Primary Bal/Balika Adrash Vidyalaya C-2, Janak Puri, New Delhi-110058 has complied with the fire prevention and fire safety requirements in accordance with the Director of Education letter No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officers concerned of fire Service on 21.11.2011 in the presence of - Smt. Baghwanti (Principal) and that the building/premises is fit for occupancy class - group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on*14/12/11*.....at New Delhi.


14/12
Chief Fire Officer
For Director
Delhi Fire Service

o/c
Mas

Ground + one

INSPECTION REPORT

1. Name & address of the building : M.C. Primary Bal. Balika Adrash Vidyalaya
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 21.11.11.
7. Name of the Inspecting Officers : D.O. H.L. Anegs
8. Name and designation of officers from the building side : Ms Bhagwati Principal
9. Year of Construction : —
10. Applicant's letter No. : Nil dt 10/10/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1	Access to building			MR/NMR
	• Road width	R	9mtrs	MR
	• Gate width	R	4.5mtrs	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	2 Nos	MR
	• Upper Floors	—	—	—
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	R	1.45 & 1.30mtrs	—
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	R	2 Nos	MR
	h. Door Size	R	1.90 mtr	MR
		R	1.10 mtr	MR

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NR	NP		
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	NR	NP		
		30 a/c per hour			
		12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	R	P.		MR
			6 Nos		MR
		ISI marked	Do type		—
			Yes		—
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NR	NP		
		30 m			
		5 mm			
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NR	NP		
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement 				

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants	NR	NP	
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	—	—	—
12	Yard Hydrants.	NR	NP	
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	—	—	—
13	Pumping Arrangements.	NR	NP	
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14	Captive Water Storage for fire fighting.	NR	NP	
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	—	—	—

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15	Exit Signage.	NR	NP	—
16	Provision of Lifts.	—	—	—
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NR	NP	—
		—	—	—
		—	—	—
		—	—	—
17	Standby power supply	—	—	—
18	Refuge Area.	NR	NP	—
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19	Fire Control Room	NR	NP	—
	<ul style="list-style-type: none"> • Detector System Panel • Fldw Switch Panel • PAi System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NP	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~..... Nil

[Handwritten Signature]

Signature of the Inspecting Officer

Name **H.L. ANEJA**

Designation **Dir. Officer**

Signature of the Inspecting Officer

Name

Designation