

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001


No: F 6/DFS/MS/2011/ *school/3558*

Dated:- *16/12/11*

FIRE SAFETY CERTIFICATE

Certified that the *All India Konark Education & Welfare Society (Mother Divine Public School)*
Block-B, Sect-3 Near Ram Lila, Road Rohini Delhi..... comprised of *Ground + Two upper*
floors with 12 class rooms..... owned/occupied by *All India*
Konark Education & Welfare Society..... Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on *23-11-11*..... in the presence of
Mr. K. K. Sharma..... and that the building/premises is fit for occupancy
Education..... building with effect from *16/12/11*..... for a period of
.....in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *16/12/11*..... at New Delhi.


Chief Fire Officer
For Director
Delhi Fire Service

Copy to:-

1. *Director of Education MS*
Old L. India College Bldg.
Kashmere Gate Delhi

2. *All India Konark Education & Welfare Society*
Block-B, Sect-3, Near Ram Lila (Road)
Rohini Delhi

Note:- This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per N.C.
 6. This N.C. may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : All India Karmark Education & Welfare Society (Mother Dilera Public School, Block-13, sec-3, Noida Dist. Delhi.
2. Type of Occupancy : Education Bldg.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : FG/DFS/MS/BSP/2005/934 dt 3.5.05
6. Date of inspection : 23.11.11
7. Name of the Inspecting Officers : Vijay Kantal
8. Name and designation of officers from the building side : Mr. K.K. Sharma
9. Year of Construction : 2005
10. Applicant's letter No. : Nil dt 19.8.11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education NBC letter dt 1.3.11 Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	P	M/R
	• Gate width	-	-	-
	• Width of internal road	N.R	N.P	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	Two stair case	M/R
	• Upper Floors	width of stair case less than 1.5 mtr additional stair case of 75 mtr required	-	-
	• Basements	-	-	-
	b. Width of staircases			
	• Upper Floors	As above in column (a)	(i) 130 cm. (ii) 106 cm	M/R
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	M/R	/	
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	N/R	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1.00 mtr	Some of class room doors less than 1 mtr width + are removed Affidavit furnished by President D.R. Sharma attached.	M/R on base of Affidavit.

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour			
		12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	CO ₂ / DCP type 20kg cap			
		ISI marked			
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1			
		30 m			
		5 mm			
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement 				

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 		/	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/R	/	downcomer system provided one
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/R	/	one
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/R	/	
		450 LPM	P	N/R
		40MPa	P	"
		-	-	-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	N/R	/	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
		10,000 ltrs	10,000 ltrs	MIR
15	Exit Signage.	R	P	MIR
16	Provision of Lifts.	No lift		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	/		
17	Standby power supply	N/R	-	
18	Refuge Area.	N/R		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	/		
19	Fire Control Room	N/R		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	/		
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	no such sps upto at present	-

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

• Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Kental
Signature of the Inspecting Officer

Name

Name *VIPIN KENTAL*

Designation

Designation *DO NOT*