

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.

F6/DFB/Ms/Indll/2011/3287

Dated: 01/12/2011

FIRE SAFETY CERTIFICATE

Certified that the M/s Century Overseas, 37 DLF Industrial Area, Kirti Nagar, New Delhi-110015, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 18.11.11 in presence of Mr. Wadhwa of the Industry and that the premises is fit for Class-G (G-1) (Industrial) occupancy with effect from01/12/2011.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....01/12/2011.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

ofc
Mr

Copy to:
Mr. Wadhwa
M/s Century Overseas, 37
DLF Industrial Area, Kirti Nagar,
New Delhi-110015.

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated 26.09-11 received from Authorised Signatory regarding of NOC in r/o M/s Century Overseas, 37 DLF Industrial Area, Kirti Nagar, New Delhi-110015. premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa

1. Name & address of the building : Century Overseas, 37, DLF Industrial Area, Kirti Nagar, New Delhi-110015.
2. Type of Occupancy : Class-G (G1) Industrial
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : F6/DFS/MS/BP/87/1568 dated 21-07-87
6. Date of inspection : 18-10-2011
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
8. Name and designation of officers
From the building side : Mr. Wadhwa
9. Year of Construction : 1992-93
10. Applicant's letter No. : nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	30 mtr	M.R.
	• Gate width	5 mtr	provided	M.R.
	• Width of internal road	3 mtr	3 mtr	M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	Provided	M.R.
	• Upper Floors	Two	Provided	M.R.
	• Basement	Two	Provided	M.R.

b. Width of staircases <ul style="list-style-type: none"> • Upper Floors • Basement c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No. of continuous staircases to terrace e. Width of Corridor f. Door size			
	As per the sectioned plan, 1.2 mtr	Provided	As per the sectioned Plan, M.R.
	As per the sectioned plan, 1.2 mtr	Provided	As per the sectioned Plan, M.R.
	Required	Provided	M.R
	Required	Provided	M.R
	N.R.	N.R.	M.R
	Two	two	M.R
	N.R. Halls only	N.R. halls only	M.R
	1.5 mtrs	1.5 mtrs	M.R.
	3.	Compartmentation.	
<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	M.R
	No shafts	No. shafts	M.R
	N.R.	N.R.	M.R
	N.R.	N.R.	M.R.
	N.R.	N.R.	M.R
4.	Smoke Management System.		
<ul style="list-style-type: none"> • Basements • Upper floors 	Required	Provided	M.R
	Required	Provided	M.R
5.	Fire Extinguishers		
<ul style="list-style-type: none"> • Total numbers • Types 	20	provided	M.R
	ABC & CO ₂ type	provided	M.R


	<ul style="list-style-type: none"> IS marking 	required	provided	M.R
6.	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	2	two	M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	provided	M.R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N.R	N.R	M.R
	<ul style="list-style-type: none"> Location of Main Panel 	N.R	N.R	M.R
	<ul style="list-style-type: none"> Location of Repeater Panel 	N.R	N.R	M.R
	<ul style="list-style-type: none"> Alternate source of power 	N.R	N.R	M.R
	<ul style="list-style-type: none"> Hooter's Location 	N.R	N.R	M.R
8.	MOEFA	N.R	Provided	M.R
9.	Public Address System.	N.R.	Provided	M.R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R
	<ul style="list-style-type: none"> Upper Floor 	N.R	N.R.	M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	No false selling	N.R.	M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	provided	M.R
	<ul style="list-style-type: none"> Number of hydrants per floor 	two	two	M.R

	• Hose Box	two	two	M.R.
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	M.R.
	• Hose Box	N.R.	N.R.	M.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2280 LPM	provided	M.R.
	➤ Head of Main pump	60 mtr	provided	M.R.
	➤ Number of main pumps	two	provided	M.R.
	➤ Jockey Pump out put	180 LPM	provided	M.R.
	➤ Jockey pump head	60 mtr	provided	M.R.
	➤ Standby pump out put	2280 LPM	provided	M.R.
	➤ Standby pump Head	60 mtr	provided	M.R.
	➤ Auto Starting/Manual stopping	required	provided	M.R.
	➤ Pump Hose Access	required	provided	M.R.
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	yes	Provided	M.R.

14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	One lack	provided	M.R. ✓
	➤ Draw -off connection	required	provided	M.R. ✓
	➤ Fire service inlet	required	provided	M.R. ✓
	➤ Access to tank	required	provided	M.R. ✓
	➤ Overhead Tank Capacity	Required 10,000 ltr	provided	M.R. ✓
15	Exit Signage.	provided	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	M.R. ✓
	• Pressurization of Lift lobby	N.R.	N.R.	M.R. ✓
	• Communication In lift Car	N.R.	N.R.	M.R. ✓
	• Fireman's Grounding Switch	N.R.	N.R.	M.R. ✓
	• Lift Signage	N.R.	N.R. ✓	M.R. ✓
17.	Standby power supply	Required ✓	60 K.V.A.	M.R.
18.	Refuge Area	N.R. ✓	N.R.	M.R.
	➤ Total Area	N.R.	N.R.	M.R.
	➤ Location	N.R. ✓	N.R.	M.R.
19.	Fire Control Room			
	➤ Detector System Panel	N.R. ✓	N.R. ✓	M.R. ✓

	➤ Flow Switch Panel	N.R.	N.R.	M.R.
	➤ PA system Panel	N.R.	N.R.	M.R.
	➤ Batter backup	N.R.	N.R.	M.R.
	➤ Building Floor plans	N.R.	N.R.	M.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	M.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/


17/11/11

Signature of the Inspection Officer

Signature of the Inspection Officer

Name D.D. Sunil Chaudhary

Name