

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS; DELHI FIRE SERVICE; CONNAUGHT PLACE; NEW DELHI

No

FG/D3/MS/2011/285

Dated

01/12/2011

FIRE SAFETY CERTIFICATE

Certified that the Delhi Institute of Rural Development (D.I.R.D) comprised of ground plus three upper floor only located at Nangli Poona Delhi-36 occupied by D.I.R.D have complied with the fire prevention and fire safety requirements under Rule 33 of the Delhi Fire rule 2010 and verified by the officer concerned of Fire Service on 23.11.11 in the presence of Sh.Anoop Singh and the building/premises is fit for occupancy Sub Group B-2 of Group B Educational Buildings with effect from 01/12/11 for a period of Three Years, subject to conditions mentioned below.

Issue on 01/12/11 at New Delhi by



Chief Fire Officer
Delhi Fire Service

gc
ms

Delhi Institute of Rural Development,
Near Kapoor Diesel Works,
GT Karnal Road,
Nangli Poona,
Delhi-36

Conditions for validity of the certificate-

- All the fire safety means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering fire safety or means of escape facilities non functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record maintained.

INSPECTION REPORT

1. Name & address of the building : Delhi Institute of Rural Development (D.I.R.D.)
Nangli Panna Delhi.
2. Type of Occupancy : Education Instg.
3. Type of Case : New Case/ Renewal *(G + three upper floors)*
4. Details of previous NOC : Letter No. — No — Dated: _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 23.11.11
7. Name of the Inspecting Officers : Vipin Kantal.
8. Name and designation of officers from the building side : sh. Anoop Singh.
9. Year of Construction : 2003-04
10. Applicant's letter No. : Nil Dt 20.10.11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mt.	6 mt	m/r
	• Gate width	5 mt.	4.7 mt	may be considered
	• Width of internal road	6 mt	6 mt	m/r
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two.	Two	m/r
	• Basements	—	—	—
	b. Width of staircases			
	• Upper Floors	150 cm.	(i) 152 cm. (ii) 138 cm.	may be considered for second floor being old case.
	• Basements	—	—	—
	c. Protection of exits			
	• Fire check door	N.R.	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	one	one	m/r
	h. Door Size	1.50 mt	1.50 mt	m/r
		1.00 mt	1.00 mt	m/r

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/R	-	-
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	6 NO. + 3 ABC type ✓ CO2 type ✓	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2 30 m 5 mm	Two 30 m/h	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/R		
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N/A		

Signature of the Inspecting Officer

Name

Designation

Kental
Signature of the Inspecting Officer

Name *VIPIN KENTAL*

Designation *DO NW*

5