

No. F6/DFS/MS/2011/3617

Dated : 19/12/11

FIRE SAFETY CERTIFICATE

Certified that the **FINE FOOD PRODUCT building** comprised of basement, ground plus two upper floors only and thus less than 15 meters located at **A-3, Phase-III, Badli Industrial Area, Delhi-110 042**, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 28.11.2011 in the presence of **Shri Rajat Arora, Proprietor** and that the building/ premises is fit for occupancy **Class Industrial Building (G-1)** with effect from 19/12/11 for a period of **3 (three)** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the condition under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on19/12/11..... at New Delhi by



**Director
Delhi Fire Service**



**Shri Rajat Arora, Proprietor
Fine Food Product,
A-3, Phase-III, Badli Industrial Area,
Delhi-110 042.**



Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

INSPECTION REPORT

1. Name & address of the building : FINE FOOD PRODUCT, BADLI INDUSTRIAL AREA
2. Type of Occupancy : INDUSTRIAL BUILDING
3. Type of Case : New Case/ Renewal
4. Details of previous NOC NA : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : As per NBC Part IV L BBL
6. Date of inspection : 28.11.2011
7. Name of the Inspecting Officers : Shri R. K. Daluys, ADO
8. Name and designation of officers from the building side : N.A.
9. Year of Construction : 2004
10. Applicant's letter No. : NIL dated MU

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 Metres	10 Metres	MR
	• Gate width	Accessible	Accessible	-u-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	Two	MR
	• Upper Floors	-u-	-u-	-u-
	• Basements	-u-	-u-	-u-
	b. Width of staircases	125 cm each	135 cm 130 cm	MR
	• Upper Floors	-u-	-u-	-u-
	• Basements	-u-	-u-	-u-
	c. Protection of exits			
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	Two	Two	MR
	g. Width of Corridor	-	-	-
	h. Door Size	100 cms	125 cms	MR


3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-	NA	-
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	-	-
5	Fire Extinguishers		Provided	
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	12 ✓ ABC Type ISI Marked	MR -u- -u-
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	Two 30 metres 5 mm	MR -u- -u-
7	Automatic fire detection and alarming system.		NA	
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	-	-	-
8	MOEFA	Not Required	-	-
9	Public Address System.	Not Required.	-	-
10	Automatic Sprinkler System.		Provided	
	<ul style="list-style-type: none"> • Basement 	Required	Provided	MR

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	-	-	-
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	Required	Provided	mR
		-	-	-
		Required	Provided	mR
12	Yard Hydrants.	N.A		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	-	-	-
		-	-	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		900 lpm	900 lpm	mR
		40 metres	40 metres	- u -
		Required	Provided	- u -
		Required	Provided	- u -
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	-	-	-
		-	-	-

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		10,000 Ltrs	12,000 Ltrs	MR
15	Exit Signage.	Repaired	Provided	MR
16	Provision of Lifts.	N.A		
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	Standby power supply	Repaired	Provided 63 KVA DG set	MR
18	Refuge Area.	N.A		
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room	N.A		
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	✓

- ✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.
- ✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

5


Signature of the Inspecting Officer

Name R. K. Dahiyas

Designation ADD

Signature of the Inspecting Officer

Name

Designation