

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**


No. F6/DFS/MS/EH/2011/3618

Dated : 19/12/11

FIRE SAFETY CERTIFICATE

Certified that M/s T' Zers Restaurant at 17, Community Center, PVR Saket, New Delhi-110017 is running at the 2nd & 3rd floor of the building comprised of basement, ground, plus three upper floor was granted NOC by this department vide letter No. F6/MS/DFS/EH/2008/2346 dated 18-08-2008. The premises was re-inspected by the officer concerned of Fire Service on 09-12-2011 in the presence of Mr. Nainjyot Singh (Owner) of the restaurant and that the building is fit for occupancy class D " Assembly Building (Restaurant)" with effect from 14/12/11 for period of three years subject to condition as mentioned below.

Issued 19/12/11 at New Delhi by.


19/12
Chief Fire Officer
For Director
Delhi Fire Service

Copy to:-

1. The DHO (South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi.
2. The Director/s T' Zers Restaurant at 17, Community Center, PVR Saket, New Delhi-110017.

Condition for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non- functional shall be the responsibility of the management.
2. Building sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provision of Building Bye Laws.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

| INSPECTION REPORT | | | | |
|-------------------|---|--|----------------------------------|--|
| 1 | Name & address of the building | M/s T.Zers Restaurant, 17, Community Centre, PVR Saket, New Delhi. | | |
| 2 | Type of Occupancy | Assembly Building "D"Restauant | | |
| 3 | Type of case | Renewal | | |
| 4 | Details of previous NOC | F6/DFS/MS/EH/2008/2346 dt 18.08.2008 | | |
| 5 | Fire safety directives letter No | Nil | | |
| 6 | Date of inspection | 09.12.2011 | | |
| 7 | Name of the inspecting Officers : | D.O. (South) D.P. Bhardwaj, ADO(BCP) S.S.Kaushik | | |
| 8 | Name and designation of officers | | | |
| | from the building side | Mr.Nainiyot Singh (Owner), | | |
| 9 | Year of construction | 1988 | Basement ground plus three upper | |
| 10 | Applicant's letter No. | Nil | 9.11.2011 | (Resturant running at 2nd and 3rd floor) |
| S. NO. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR / NMR |
| 1 | Access to building | | | |
| | 1) Road width | Required | 24 Mtr Provided | MR |
| | 2) Gate width | Required | 1.5 mtr Resturant Gate P | MR |
| | 3) Width of internal road | Not Required | Not Required | MR |
| 2 | Number, width Type & arrangement of exits | | | |
| | a. Number of staircases | | One Stair Provided | |
| | 1. Upper floors | Old Case | | MR (Old Case) |
| | 2. basements | Old Case | One Stair Provided | MR (Old Case) |
| | b. Width of staircase | | | |
| | 1. Upper floors | 1.25 Mtr | 119 cm Provided | MR (Old Case) |
| | 2. basements | 1.25 Mtr | 119 cm Provided | MR (Old Case) |
| | c. Protection of exits | | | |
| | 1. Fire check door | Required | Provided | MR |
| | 2. Pressurization | Not Required | Not Required | MR |
| | d. No. of continuous staircase to terrace | Required | 1 Nos. Stair Provided | MR |
| | e. Width of corridor | Not Required | Not Required | MR |
| | f. Door size | 1.5 Mtr (2 exit) | Provided | MR |
| 3 | Compartmentation. | | | |
| | 1. Fire check door | Required | Provided | MR |
| | 2. Sealing of electrical shafts | Not Required | Not Required | MR |
| | 3. Fire Rating of shaft door | Not Required | Not Required | MR |
| | 4. water curtain | Not Required | Not Required | MR |
| | 5. Fire dampers | Not Required | Not Required | MR |
| 4 | Smoke Management system. | | | |
| | basement | 30 a/c per hour 12 a/c per hour | N/A | MR |
| | upper floors | | Exhust Fans Provided | MR |
| 5 | Fire Extinguishers | | | |
| | total numbers | | 12 Nos | MR |
| | Types | | ABC, Co2 | MR |
| | ISI marking | ISI | Yes | MR |
| 6 | First-Aid Hose Reels. | | | |
| | total numbers on each floor | One | Provided | MR |
| | Length of Hose reel hose | 30 m | Provided | MR |
| | Nozzle Diameter | 5 mm | Provided | MR |

| | | | | |
|-----------|---|---------------|--------------|----|
| 7 | Automatic fire detection and alarming system | | | |
| | Type of detectors | Not Required | Not Required | MR |
| | location of Main Panel | Not Required | Not Required | MR |
| | location of Repeater panel | Not Required | Not Required | MR |
| | Alternate source of power | Not Required | Not Required | MR |
| | hooter's location | Not Required | Not Required | MR |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | basement | Not Required | Not Required | MR |
| | upper floors | Required | Provided | MR |
| | sprinkler above false ceiling | Not Required | Not Required | MR |
| 11 | Internal Hydrants | | | |
| | Size of riser/down-corner | 100 mm | Provided | MR |
| | Number of Hydrants per floor | One | Provided | MR |
| | hose Box | One | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | total number of hydrants | Not Required | Not Required | MR |
| | hose box | Not Required | Not Required | MR |
| 13 | Pumping arrangements | | | |
| | 1. Ground level | | | |
| | a. Discharge of main Pump | Not Required | Not Required | MR |
| | b. Head of main pump | Not Required | Not Required | MR |
| | c. Number of main pumps | Not Required | Not Required | MR |
| | d. jockey pump out put | Not Required | Not Required | MR |
| | e. jockey pump head | Not Required | Not Required | MR |
| | f. Standby Pump output | Not Required | Not Required | MR |
| | g. Stanby Pump head | Not Required | Not Required | MR |
| | h. Auto Starting/Manual stopping | Not Required | Not Required | MR |
| | pump house access | Not Required | Not Required | MR |
| | 2. Terrace level | | | |
| | a. Discharge of pump | 450 & 180 LPM | Provided | MR |
| | b. head of the pump | 40 mtr | Provided | MR |
| | c. Power supply | Required | Provided | MR |
| | d. Auto starting of pump | Required | Provided | MR |
| 14 | Captive water storage for fire fighting | | | |
| | 1. Underground tank capacity | Not Required | Not Required | MR |
| | a. Draw-off connection | Not Required | Not Required | MR |
| | b. fire service inlet | Not Required | Not Required | MR |
| | c. Access to tank | Not Required | Not Required | MR |
| | Over head tank Capacity | 5,000 ltr | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of lifts. | | | |
| | a. Pressurization of lift shaft | Not Required | Not Required | MR |
| | b. pressurization of lift lobby | Not Required | Not Required | |
| | c. communication in lift car | Required | Provided | MR |
| | d. Fireman's grounding switch | Required | Provided | MR |
| | e. Lift signage | Not Required | Not Required | MR |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | Not Required | | |
| | total area | | | |
| | location | | | |

| | | | | |
|-----------|---|--------------|--------------|----|
| 19 | Fire control room | | | |
| | a. detector system Panel | Not Required | Not Required | MR |
| | b. Flow switch Panel | Not Required | Not Required | MR |
| | c. PA system Panel | Not Required | Not Required | MR |
| | d. Batter backup | Not Required | Not Required | MR |
| | e. Building floor plans | Not Required | Not Required | MR |
| 20 | Special Fire Protection systems for protection of special risks, if any: | | | |
| | | | | |

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)

Signature of the Inspecting Officer

Name

Designatic

S.S. Kaushik

A.D.O. (BCP)