

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**


No. F6/DFS/MS/EH/2011/3254

Dated: 29/11/11

FIRE SAFETY CERTIFICATE

Certified that the **Smoke House Grill** located at (**Ground & Mezzanine Floor**), **Plot No.2, Local Shopping Complex, Masjid Moth, Greater Kailash-II, New Delhi-110048**. comprised of **Basement, Ground, Mezzanine + 7 Upper Floors** was granted NOC in the name of **Opera Restaurant (Unit of Lotus Hospitality Pvt. Ltd.)** by this department vide letter No. **F6/DFS/MS/EH/2008/2467** dated **29/08/08** The premises was re-inspected by the officer concerned of this department on **13/11/11** in the presence of **Mr. Vishal Chauhan** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly Building** with effect from **21/11/11** for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire subject to conditions printed overleaf.

Issued 29/11/11 at New Delhi by.



**Chief Fire Officer
For Director
Delhi Fire Service**

- Copy to:- (1) The Dy. Health Officer,
South Zone, Green Park, Municipal
Corporation of Delhi, New Delhi.
- (2) Smoke House Grill, Plot No.2,
Local Shopping Complex, Masjid Moth,
Greater Kailash-II, New Delhi-110048.

07/11/11

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

-2/6-

INSPECTION REPORT

1. Name & address of the building:- Smoke House Grill, Plot No.2, Local Shopping Complex, Masjid Moth, Greater Kailash-II, New Delhi-110048.
2. Type of occupancy:- Assembly Building.
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/EH/2008/2467 dated 29/08/08
5. Fire safety directives No.- No
6. Date of inspection:- 13/11/11
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Vishal Chauhan
9. Year of construction:- N/A
10. Applicant's letter No:- Nil dated 03/10/11

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	abutting on motorable Rd	Situated on main Road
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases	Required	Provided	MR
	1. Upper floors	Required	Mezzanine & Ground Floor	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase	N/A	N/A	N/A
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Two exits	Provided	old case
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	06 Nos.	MR
	2) Types		Co2, W.Co2 & ABC	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	One at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A

	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	Provided	MR
	2) Number of hydrants per floor	Required	One	MR
	3) Hose box	Required	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	Required	450 LPM	MR
	b) Head of main pump	Required	35 mtr.	MR
	c) Number of main pump	Required	One	MR
	d) Jockey pump out put	Required	180 LPM	MR
	e) Jockey pump head	Required	35 mtr.	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	15,000 Ltr.	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	Required	5,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	N/A	N/A	N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A

20

Special Fire Protection systems for protection of special risks, if any:

The fire protection systems provided in the building were checked and found functional at the time of inspection. under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules e Delhi Fire Service Rules 2010/~~issue Shortcomings as noted as serial numbers.....~~

Accordingly OPA is put up

Signature of the inspecting officer

Name

Designation :

Signature of the Inspecting Officer

Name

Designatic

S. S. Kaushik

Asst Div. Officer