

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No. F6/DFS/MS/EH/2011/32576

Dated : 29/11/11

FIRE SAFETY CERTIFICATE

Certified that the **Sky Gourmet Catering Pvt. Ltd.**, located at **IGI Airport Complex, New Delhi-110037**, comprised of **Ground + 1 Upper Floors** was granted NOC by this department vide letter No. **F6/MS/DFS/EH/2009/1874** dated **25/06/09**. The premises was re-inspected by the officer concerned of this department on **29/09/11** in the presence of **Mr. Ghanshyam** and found that the said eating house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Eating House Assembly Building** with effect from **21/11/11** for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire subject to conditions printed overleaf.

Issued 29/11/11 at New Delhi by.



**Chief Fire Officer
For Director
Delhi Fire Service**

Copy to:- (1) Dy. Health Officer,
Municipal Corporation of Delhi,
Health Department Najafgarh Zone, New Delhi.

(2) Sky Gourmet Catering Pvt. Ltd.,
IGI Airport Complex, New Delhi-110037.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

11/4
INSPECTION REPORT

1. Name & address of the building:- Sky Gourmet Catering Pvt. Ltd., IGI Airport Complex, New Delhi-110037
2. Type of occupancy:- Eating House
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/EH/2009/1874 dated 25/06/09
5. Fire safety directives No.- No
6. Date of inspection:- 29/09/11
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer } *Ghanshyam*
From the building side:-
9. Year of construction:- 2008
10. Applicant's letter No:- DHO/NGZ/2011/4341 dated 11/07/11

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	10 mtr. provided	MR
	2) Gate width	Required	4 mtr. provided	MR
	3) Width of internal road	Required	8 mtr provided	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases	Required	Two	MR
	1. Upper floors	Required	Three provided	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	Required	1.50 mtr. provided	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	Required	1.50 mtr. provided	MR
	F. Door size	<i>NA</i>	<i>NA</i>	<i>NA</i>
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan provided	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	39 Nos. provided	MR
	2) Types		w.co2.ABC & M.foam	MR
	3) ISI marking		yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	Two provided	MR
	2) Length of hose reel hose	30 m	provided	MR

	3) Nozzle diameter	5 mm	provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	100 mm	MR old case
	2) Number of hydrants per floor	Required	Two at each floor	MR
	3) Hose box	Required	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Four provided	MR old case
	2) Hose box	Required	Provided	MR
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	Required	900 LPM	MR ✓
	b) Head of main pump	Required	40m	MR ✓
	c) Number of main pump	Required	one	MR ✓
	d) Jockey pump output	Required	180 LPM	MR ✓
	e) Jockey pump head		40m	
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Jockey Auto starting/Manual stopping	MR
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	Required	1,00,000 Ltr	MR ✓
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	Not required old case	Not provided	Old case
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	D.G. Set provided	MR
18.	Refuge Area	N/A	N/A	N/A

A/B

	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers-----

Accordingly, DSA is put up M

Signature of the inspecting officer

Signature of the inspecting officer

Name

Name

Designation

Designation

S. S. Kanshuk

Asst Dir. Officer