

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110 001.

No. FG/DFB/MS/Cos/2011/3264

Dated : 30/11/2011

FIRE SAFETY CERTIFICATE

Certified that the **SHRADHA COSMETICS building** comprised of basement, ground plus three upper floors only and thus less than 15 meters located at **H-258, Sector-3, Bawana Industrial Area, Delhi-110 039**, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 26.11.2011 in the presence of **Shri Rinku, Manager** and that the building/ premises is fit for occupancy **Class Industrial Building** with effect from 30/11/2011 for a period of **3 (three)** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the condition under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/11/2011 at New Delhi by



Director

Delhi Fire Service



**Shri Rinku, Manager
SHRADHA COSMETICS,
H-258, Sector-3,
Bawana Industrial Area,
Delhi-110 039.**

Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

old copy

①

INSPECTION REPORT

1. Name & address of the building : SHRADHA COSMETICS, BAWANA IND. AREA
2. Type of Occupancy : FACTORY
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F.5(3)/DAS/2006/90 Dated: 28/02/06
5. Fire Safety directives letter No : .
6. Date of inspection : 26/11/2011
7. Name of the Inspecting Officers : SHRI R.K. DAHIYA, ADO
8. Name and designation of officers from the building side : N.A.
9. Year of Construction : 2005
10. Applicant's letter No. : 023 dated 02.11.2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 Metres	10 metres	-MR-
	• Gate width	5 metres	6 metres	-u-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	One	One	MR
	• Upper Floors	-u-	-u-	-u-
	• Basements	-u-	-u-	-u-
	b. Width of staircases	125 cms	125 cms	MR
	• Upper Floors	-u-	-u-	-u-
	• Basements	-u-	-u-	-u-
	c. Protection of exits			
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	One	One	-MR-
	g. Width of Corridor	-	-	-
	h. Door Size	-	-	-

3	Compartmentation.		N.A	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-	-	-
4	Smoke Management System.		N.A	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	-	-
5	Fire Extinguishers		Provided	
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	Ten (10) ABC Type ISI Marked	mR -u- -u-
6	First-Aid Hose Reels.		Provided	
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	Three 30 m 5 mm	mR -u- -u-
7	Automatic fire detection and alarming system.		N.A	
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	-	-	-
8	MOEFA		NA	
9	Public Address System.		NA	
10	Automatic Sprinkler System.		Provided	
	<ul style="list-style-type: none"> • Basement 	Required	Provided	mR

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	Not Rectified	Provided	MR
		-	-	-
11	Internal Hydrants		NA	
	<ul style="list-style-type: none"> • Size of riser/down-comer 	-	-	-
	<ul style="list-style-type: none"> • Number of hydrants per floor 	-	-	-
	<ul style="list-style-type: none"> • Hose Box 	-	-	-
12	Yard Hydrants.		NA	
	<ul style="list-style-type: none"> • Total number of hydrants 	-	-	-
	<ul style="list-style-type: none"> • Hose Box 	-	-	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level 	-	-	-
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	-	-	-
	<ul style="list-style-type: none"> ➤ Head of Main pump 	-	-	-
	<ul style="list-style-type: none"> ➤ Number of main pumps 	-	-	-
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	-	-	-
	<ul style="list-style-type: none"> ➤ Jockey pump head 	-	-	-
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	-	-	-
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	-	-	-
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	-	-	-
	<ul style="list-style-type: none"> ➤ Pump House Access 	-	-	-
	<ul style="list-style-type: none"> • Terrace level 	Repaired	Provided	MR
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900 lpm	900 lpm	-u-
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 mhrs	40 mhrs	-u-
	<ul style="list-style-type: none"> ➤ Power Supply 	-	-	-
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	-	-	-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	-	-	-
	<ul style="list-style-type: none"> ➤ Draw-off connection 	-	-	-

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	-	-
		10,000	10,000	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	NA		
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	Standby power supply	-	NA	-
18	Refuge Area.	NA		
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room	NA		
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

5

R.K. Dahiya

Signature of the Inspecting Officer

Name R.K. DAHIYA

Designation ADO

Signature of the Inspecting Officer

Name

Designation