

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2011 / GH / 3532

Dated 15/12/11


FIRE SAFETY CERTIFICATE

Certified that the Mugal Guest House, located at 11, Bazar Matia Mahal, Jama Masjid Delhi-06 comprised of Ground + three upper floors having 05 Guest rooms (Ground floor is used for commercial purpose, First floor has 02 rooms + Reception, Second floor has 05 guest rooms, third floor has 02 staff rooms + staff kitchen) was granted NOC by this department vide letter No F 6 / DFS / MS / GH / 2009 / 04 dated 01.01.2009. The premise was re-inspected by the officer concerned of this department on 30.11.2011 in the presence of Mr. Md. Safdar (employee of guest house) found that the said Guest House have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" A-I with effect from 15/12/11... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/12/11..... at New Delhi



Chief Fire Officer
For Director
Delhi Fire Service



Copy to: -

1. The Addl. Comm. of Police (Lic) First Floor, Police Station Defence Colony, New Delhi.
2. The Owner, Mugal Guest House, located at 11, Bazar Matia Mahal, Jama Masjid Delhi-06

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Building covered under special area
 L. No. F-6/MS/DFS/2001/1795 dated 29-8-2001

INSPECTION REPORT

1. Name & address of the building : Mugal Guest House, 11, Bazar Matia Mahal, Jama-
2. Type of Occupancy : Group A-1, Residential - Masjid, Delhi-6.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/MS/DFS/GH/09/04 Dated: 01/01/2009.
5. Fire Safety directives letter No : F-6/MS/DFS/GH/2000/1999 dt. 24/08 & F-6/MS/DFS/GH/01/292/dt. 19/01.
6. Date of inspection : F-6/MS/DFS/GH/01/218 dt. 25-6-2001.
30-11-2011.
7. Name of the Inspecting Officers : ADO - SHYAM LAL.
8. Name and designation of officers Guest House employee - Md. Saifdar.
from the building side : _____
9. Year of Construction : 1946, (9 beds in 5 Guest Rooms at Ist & IInd floor.)
10. Applicant's letter No. : _____

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circulars G. H. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	N/A	6 mtrs.	M R
	• Gate width	N/A	—	
	• Width of internal road	N/A	—	
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	one	one	M R
	• Upper Floors	one	one	M R
	• Basements	N/A	NIL	
	b. Width of staircases	80 cm	80cm to 95cm.	M R
	• Upper Floors	80 cm	80 to 95cm.	M R
	• Basements	—	NIL	—
	c. Protection of exits			
	• Fire check door		N/A	Being old Cor.
	• Pressurization			
	e. No. of continuous staircases to terrace	one	one	M R
	g. Width of Corridor	N/A	—	old Cor
	h. Door Size	N/A	—	old Cor

3	Compartmentation.		N/A	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A		old door
		N/A		
		N/A		
		N/A		
4	Smoke Management System.		N/A	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	6 W.C02 = 4 C02 2kg = 1 ABC 5kg = 1 yes	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	_____ 30 m 5 mm	one yes yes	MR MR MR
7	Automatic fire detection and alarming system.		N/A	
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A N/A N/A N/A N/A		
8	MOEFA	N/A	N/A	
9	Public Address System.	N/A	N/A	
10	Automatic Sprinkler System.	N/A		
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A		
		N/A		
		2500L	2500L	MR
15	Exit Signage.	staircase	provided	
16	Provision of Lifts.		N/A	
	• Pressurization of Lift Shaft	N/A		
	• Pressurization of Lift lobby	N/A		
	• Communication In lift Car	N/A		
	• Fireman's Grounding Switch	N/A		
	• Lift Signage	N/A		
17	Standby power supply		N/A	
18	Refuge Area.		N/A	
	➤ Total Area			
	➤ Location			
19	Fire Control Room		N/A	
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:		Nil	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....~~X~~.....

5

Signature of the Inspecting Officer

Name

Designation

D.O. (C)

Shylal
02/12/2011

Signature of the Inspecting Officer

Name SHYAM LAL

Designation Assitt. Divn. Officer.