

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO. F6/DFS/MS/EH/2011/3650

DATED: 21/12/11

FIRE SAFETY CERTIFICATE

Certified that the M/s Moti Mahal Deluxe Restaurant, 11 central Market, Defence Colony, New Delhi- is running at the ground plus two and half upper floors, comprised of basement, ground plus two upper floors (basement use for storage) was granted NOC by this department vide letter no. F6/MS/DFS/EH/2008/2206 Dated 31.07.2008. The premises re-inspected by the officers concerned of Fire Service on 25.11.2011 in the presence of Mr. James (Manager), of the restaurant and that the building is fit for occupancy class D "Assembly Building (Restaurant) " with effect from.....21/12/11. for a period of **three years**, subject to conditions as mentioned below.

Issued on ...21/12/11..... at New Delhi by


Chief Fire Officer
For Director
Delhi Fire Service

Copy To:-

1. The DHO(South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi.
2. The Manager, M/s Moti Mahal Deluxe Restaurant, 11 central Market, Defence Colony, New Delhi

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/s Moti Mahal Delux Restaurant 11 Defence Colony New Delhi		
2	Type of Occupancy	Assambly "D"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/EH/2008/2206 Dated 31.07.2008		
5	Fire safety directives letter No	Nil		
6	Date of inspection	25.11.2011		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO(BCP) S.S.Kaushik		
8	Name and designation of officers	Mr.James (Manager)		
9	Year of construction	1965	(Basement,Ground, plus two and half upper floors)	
10	Applicant's letter No.	Nil	Dt. 11.11.2011	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	10 mtrs	Provided	MR
	2) Gate width	N/A	N/A	MR
	3) Width of internal road	N/A	N/A	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases	2 Nos		
	1. Upper floors	Required	2 Nos Provided	MR
	2. basements	Required	2 Nos Provided	MR
	b. Width of staircase			
	1. Upper floors	1.25 mtrs	90 cm & 65 cm Provided	MR
	2. basements	1.25 mtrs	90 cm & 65 cm Provided	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	MR
	d. No. of continuous staircase to terrace	Required	One	MR
	e. Width of corridor	N/A	N/A	MR
	f. Door size	1.5 mtrs (2 Nos)	(122cm & 90cm)Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	N/A	N/A	MR
	3. Fire Rating of shaft door	N/A	N/A	MR
	4. water curtain	N/A	N/A	MR
	5. Fire dampers	N/A	N/A	MR
4	Smoke Management system.			
	basement	30 a/c per hour	Exhust Fans Provided	MR
		12 a/c per hour		
	upper floors		Narural Ventilation	MR
5	Fire Extinguishers			
	total numbers		16 Nos	MR
	Types		ABC, Co2, W.Co2	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	1 Nos.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR

7	Automatic fire detection and alarming system			
	Type of detectors	Required	Provided (Smoke)	MR
	location of Main Panel	Required	Ground	MR
	location of Repeater panel	N/A	N/A	MR
	Alternate source of power	Required	Battery Backup	MR
	hooter's location	Staircase	Provided	MR
8	MOEFA	Required	Provided by Mall	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	MR
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	Required	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	MR
	hose box	N/A	N/A	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	MR
	b. Head of main pump	N/A	N/A	MR
	c. Number of main pumps	N/A	N/A	MR
	d. jockey pump out put	N/A	N/A	MR
	e. jockey pump head	N/A	N/A	MR
	f. Standby Pump output	N/A	N/A	MR
	g. Stanby Pump head	N/A	N/A	MR
	h. Auto Starting/Manual stopping	N/A	N/A	MR
	pump house access	N/A	N/A	MR
	2. Terrace level			
	a. Discharge of pump	450 LPM & 180 LPM	Provided	MR
	b. head of the pump	40 mtr	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	Provided	MR
	a. Draw-off connection	N/A	Provided	MR
	b. fire service inlet	N/A	Provided	MR
	c. Access to tank	N/A	Provided	MR
	Over head tank Capacity	5,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	MR
	b. pressurization of lift lobby	N/A	N/A	MR
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			

19	Fire control room			
	a. detector system Panel	N/A	N/A	MR
	b. Flow switch Panel	N/A	N/A	MR
	c. PA system Panel	N/A	N/A	MR
	d. Batter backup	N/A	N/A	MR
	e. Building floor plans	N/A	N/A	MR

20 **Special Fire Protection systems for protection of special risks, if any:**

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. The grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ May be recommended for the said restaurant subject to conditions given in the letter Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)

Signature of the Inspecting Officer

Name

Designation

S.S. Kaushik

ADO (BCP)