

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001.

No. F6/DFS/MS/EH/2011/3122

Dated: 23/11/11

FIRE SAFETY CERTIFICATE

Certified that the **McDonald's Restaurant** located at 6A-6B, Sonia Cinema Complex, Vikas Puri, New Delhi-110018. The restaurant is running at Ground floor, First floor & Basement only. Above restaurant was issued NOC vide this office letter No.F.6/DFS/MS/EH/2008/2321 dated 13.08.2008 owned/ occupied by Sh. Vikram Bakshi have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 22.10.2011 in the presence of Sh Ravi Arora. There is no additional construction and that the building/ premises is fit for occupancy class Group D Assembly building Sub- Division D-6 w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....23/11/11..... at New Delhi.



CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to: -

1. Mr. Vikram Bakshi (Owner)  
McDonald's Restaurant,  
6A-6B, Sonia Cinema Complex,  
Vikas Puri, New Delhi - 110018.



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building : McDonald's, 6A-6B, Senia Cinema Complex, Vikas Puri
2. Type of Occupancy : Assembly Building, Group - D No. D-18
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. P.C/DES/MS/EH/08/2321 Date 13.08.08
5. Fire Safety directives letter No : NIA
6. Date of inspection : 22.10.2011
7. Name of Inspecting Officer : D.O H.L. Aneja & A.D.O P.S. Dahiya
8. Name and designation of officers  
From the building side : Mr. Ravi Arora
9. Year of Construction : Before 2007
10. Applicant's letter No. : NIA dated 09.08.2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>-</li> <li>-</li> </ul>	<ul style="list-style-type: none"> <li>12 mtr</li> <li>180cm</li> <li>06 mtr</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR, Being Old Case</li> <li>MR</li> </ul>
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	Two	Two	MR
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<ul style="list-style-type: none"> <li>-do-</li> <li>-do-</li> </ul>	<ul style="list-style-type: none"> <li>-do-</li> <li>-do-</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> </ul>
	b. Width of staircases	-	121cm, 134cm	MR, Being Old Case
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	-	-do-	-do-
	c. Protection of exits	-	120cm, 112cm	-do-
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• pressurization</li> </ul>	-	Provided	MR
	d. No. of continuous staircases to terrace	-	One	-
	e. Width of Corridor	-	160cm	-
	f. Door Size	-	100cm x 204cm	-
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<ul style="list-style-type: none"> <li>NIA</li> <li>NIA</li> <li>NIA</li> <li>NIA</li> <li>NIA</li> </ul>	<ul style="list-style-type: none"> <li>-</li> <li>Sealed</li> <li>-</li> <li>-</li> <li>-</li> </ul>	<ul style="list-style-type: none"> <li>-</li> <li>-</li> <li>-</li> <li>-</li> <li>-</li> </ul>
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	<ul style="list-style-type: none"> <li>Exhaust Fans are Provided</li> <li>Natural Ventilation</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> </ul>


		12 a/c per hour	-	-
5.	<b>Fire Extinguishers</b>			
	• Total numbers	Two at each floor	06 A.B.C type Cap-Sky each	MR
	• Types	A.B.C. Cap-Sky	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	N/A	Smoke & Heat type Provided	MR
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	Provided	MR
	• Hooters' Location	-	-	-
8.	<b>MOEFA</b>			
		Required	Provided	MR
9.	<b>Public Address System</b>			
		Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	- do -	- do -	MR
	• Sprinkler above false ceiling	-	-	-
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	-	Provided	MR
	• Number of hydrants per floor	-	Provided	MR
	• Hose Box	-	Provided	MR
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	2250 L.P.M	2250 L.P.M	MR
	➤ Head of Main pump	-	80 m	MR
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	900 L.P.M	MR
	➤ Jockey pump head	-	30 m	MR
	➤ Standby Pump out put	-	2250 L.P.M & 450 L.P.M	MR
	➤ Standby Pump Head	-	88 m & 30 m	MR
	➤ Auto Starting/Manual stopping	-	Both	MR

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	-	Provided	MR
		-	-	-
		Required	Provided	MR
		-	-	-
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	-	120000 Ltr	MR
		-	Provided	MR
		-	- do -	MR
		-	- do -	MR
		-	30000 Ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
17.	<b>Standby power supply</b>	-	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	-	-
		N/A	-	-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	-	Basement	-
		-	-	-
		-	-	-
		-	Provided	MR
		-	-	-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to <sup>Renewal</sup> grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~


Note:- The Restaurant is situated at Ground floor, First floor and basement of Sonia Cinema Complex, having two exits.



Signature of Inspecting Officer

Name H. L. Aneja

Designation Divisional Officer



Signature of Inspecting Officer

Name P. S. Dahiya

Designation Asst. Divisional Officer.