

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


NO. F6/DFS/MS/EH/2011/01

DATED: 02/01/12

FIRE SAFETY CERTIFICATE

Certified that the M/s Blue Frog Restaurant (Unit of Blue Frog Media Pvt. Ltd.) at The Kila, 4-A, Kalkadas Marg, Mehrauli New Delhi-110030 is running at the ground floor, comprised of only ground owned/occupied by M/s Blue Frog Restaurant (only for restaurant) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 22.12.2011 in the presence of Mr. Mahesh Mathai (Director), of the restaurant and that the building is fit for occupancy class D "Assembly building (Restaurant)" with effect from...02/01/12 for a period of **three** years subject to condition as mentioned below.

Issued on ...02/01/12... at New Delhi by


Chief Fire Officer
For Director
Delhi Fire Service

Copy To:-

1. The Dy. Health Officer(South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi.
2. The Director, Blue Frog Restaurant (Unit of Blue Frog Media Pvt. Ltd.) at The Kila, 4-A, Kalkadas Marg, Mehrauli New Delhi-110030

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/s Blue Frog Resturant (Unit of Blue Frog Media Pvt Ltd) at The Kila, 4-A, Kalkadas Marg, Mehrauli New Delhi-110030		
2	Type of Occupancy	Assembly "D" <i>Resturant</i>		
3	Type of case	New for Resturant		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	Nil		
6	Date of inspection	22.12.2011		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO(BCP/SJ) S.S.Kaushik		
8	Name and designation of officers from the building side	Mr.Mahesh Mathai (Director)		
9	Year of construction	1960		
10	Applicant's letter No.	D/2645/DHO/52	04.11.2011	Only ground floor
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	12 mtrs ✓	Provided	MR
	2) Gate width	2mtrs ✓	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.5 mtrs (3 No. Exit) ✓	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	Required	Provided	MR
	5. Fire dampers	Required	Provided	MR
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		N/A	N/A
5	Fire Extinguishers			
	total numbers		15 Nos	MR
	Types		ABC, Co2,	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	2 Nos. ✓	Provided	MR
	Length of Hose reel hose	30 m ✓	Provided	MR
	Nozzle Diameter	5 mm ✓	Provided	MR

7	Automatic fire detection and alarming system			
	Type of detectors	Required	Provided (Smoke & heat)	MR
	location of Main Panel	Required	Provided in Kitchan	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battary Backup	MR
	hooter's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	One	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	450 LPM	Provided	MR
	b. Head of main pump	40 Mtr	Provided	MR
	c. Number of main pumps	One	Provided	MR
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	Required	Provided (Both)	MR
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	20,000 Ltrs	Provided	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided b	MR
18	Refuge Area.	Not Required		
	total area			
	location			

19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

20 Special Fire Protection systems for protection of special risks, if any:

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. The grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ May be recommended for the said restaurant subject to conditions give in the letter Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)

Signature of the Inspecting Officer

Name

S.S. Kaushik

Designation

ADO (BCP)