

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No F 6 / DFS / MS / 2011 / GH / 3739

Dated 29/12/11

**FIRE SAFETY CERTIFICATE**

Certified that the Duke Guest House, located at 5043-44/8 Netaji Subhash Marg, New Delhi comprised of Ground + three upper floors having 12 rooms (Ground floor is used for commercial purpose, First floor has 06 rooms + reception + Kitchen, Second floor has 06 rooms, Third floor has tin shed for staff and office purpose + DG Set) was granted NOC by this department vide letter No F 6 / DFS / MS / GH / 2008 / 3268 dated 27.11.2008. The premise was re-inspected by the officer concerned of this department on 21.12.2011 in the presence of Mr. C.S. Dev (Manager) found that the said Guest House have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" A-I with effect from ..29/12/11.. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..29/12/11..... at New Delhi



Director  
Delhi Fire Service

Copy to: -

1. The Addl. Comm. of Police (Lic) First Floor, Police Station Defence Colony, New Delhi.
2. The Owner, Duke Guest House, located at 5043-44/8 Netaji Subhash Marg, New Delhi



Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. This NOC is for Guest Rooms only.

Building covered under Special area

L.No. F.6/MS/DFS/2001/1795 dated 29.8.2001

**INSPECTION REPORT**

1. Name & address of the building : Duke Guest House 8, Netaji Subhash Marg Darya  
Gatki New Delhi
2. Type of Occupancy : Group A-1, Residential
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F.6/MS/DFS/08/3268 Dated: 27.11.08
5. Fire Safety directives letter No F6/MS/DFS/GH/2000/1999 dt. 2/11/2000 & F6/MS/DFS/GH/01/292/1997  
A F6/MS/DFS/GH/01/248 dt 2-5-01
6. Date of inspection : 21-12-2011
7. Name of the Inspecting Officers : A.D.O - SHYAM LAL
8. Name and designation of officers  
from the building side : Manager C.S. Dev.
9. Year of Construction : 1944 (15 beds in 12 rooms at Ist & II nd floor)
10. Applicant's letter No. :

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circulars G.H Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	C	9 mtrs.	MR
	• Gate width	N/A	-	MR
	• Width of internal road	N/A	-	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	one	one	MR
	• Upper Floors	one	one	MR
	• Basements	N/A	NIL	
	b. Width of staircases			
	• Upper Floors	80cm	88 to 90cm.	MR
	• Basements	N/A	NIL	MR
	c. Protection of exits			
	• Fire check door	N/A	N/R	
	• Pressurization	N/A	N/R	
	e. No. of continuous staircases to terrace	one	one	MR
	g. Width of Corridor	N/A	-	
	h. Door Size	N/A	-	

3	<b>Compartmentation.</b>		N/R	
	• Fire check door	N/A		
	• Sealing of electrical shafts	N/A		
	• Fire Rating of shaft door	N/A		
	• Water Curtain	N/A		
	• Fire Dampers	N/A		
4	<b>Smoke Management System.</b>		N/R	
	• Basements	30 a/c per hour	N/A	
	• Upper floors	12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	• Total numbers		6	MR
	• Types		CO <sub>2</sub> 4.5 kg. Water CO <sub>2</sub>	
	• IS marking	ISI marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on <sup>second</sup> each floor	one	one	MR
	• Length of hose reel hose	30 m	Yes	MR
	• Nozzle diameter	5 mm	Yes	MR
7	<b>Automatic fire detection and alarming system.</b>		N/R	
	• Type of detectors	N/A		MR
	• Location of Main Panel	N/A		MR
	• Location of Repeater Panel	N/A		MR
	• Alternate source of power	N/A		MR
	• Hooters' Location	N/A		MR
8	<b>MOEFA</b>	N/A	N/R	
9	<b>Public Address System.</b>	N/A	Provided	MR
10	<b>Automatic Sprinkler System.</b>		N/R	
	• Basement	N/A		

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	N/A		
		N/A		
11	<b>Internal Hydrants</b>		N/R	
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	N/A		
		N/A		
		N/A		
12	<b>Yard Hydrants.</b>		N/R	
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	N/A		
		N/A		
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/R	
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		yes	yes	yes
		N/A		
		225 lpm	225 ltr. P/Minut	M L
			40 mtr.	
			-	
			-	
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>	N/A	N/R	
		N/A		

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A		
		N/A		
		-	2500 ltr	MR
15	<b>Exit Signage.</b>	Y	Provided	MR
16	<b>Provision of Lifts.</b>	N/A		
	• Pressurization of Lift Shaft	N/A		
	• Pressurization of Lift lobby	N/A		
	• Communication In lift Car	N/A		
	• Fireman's Grounding Switch	N/A		
	• Lift Signage	N/A		
17	<b>Standby power supply</b>	N/A	NIR	
18	<b>Refuge Area.</b>	N/A		
	➤ Total Area	N/A		
	➤ Location	N/A		
19	<b>Fire Control Room</b>	N/A		
	• Detector System Panel	N/A		
	• Flow Switch Panel	N/A		
	• PA System Panel	N/A		
	• Batter backup	N/A		
	• Building Floor Plans	N/A		
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	NIL	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers...X.....

Signature of the Inspecting Officer

Name

Designation

D-0 (CP)

*Shylal*  
23/12/2011

Signature of the Inspecting Officer

Name

SHYAM LAL

Designation

Assist. Divn. officer.