

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/EH/2011/3688

Dated: 23/12/11

FIRE SAFETY CERTIFICATE

Certified that M/s **Gola Restaurant located at K-24, Connaught Place, New Delhi** comprised of **ground & Mezzanine floor** was granted NOC by this department vide letter No. F.6/DFS/MS/EH/2008/2820 dated 07-10-2008. The premises was re-inspected by the officer concerned of this department on 25-11-2011 in the presence of Mr. Mukesh Khanna, Manager of the restaurant and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **Assembly (Restaurant)** with effect from -- ~~23/12/11~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on ~~23/12/11~~ at New Delhi by.


Chief Fire Officer
Delhi fire service

Copy to: -

1. The Medical Officer of Health, Health Department, Palika Kendra, Sansad Marg, New Delhi
2. The Authorized Signatory, Gola Restaurant, K-24, Connaught Place, New Delhi.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

74

Old Case

INSPECTION REPORT

1. Name & address of the building : Gola Restaurant, K-24
2. Type of Occupancy : Restaurant
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. FG/D/Fc/MS/EH/08/2820 Dated: 7/10/2008
5. Fire Safety directives letter No : -
6. Date of inspection : 25/11/2011
7. Name of the Inspecting Officers : M.K. Chattopadhyay, ADO
8. Name and designation of officers from the building side : Mr. Mukesh (Manager)
9. Year of Construction : not known
10. Applicant's letter No. : MOH/1030/CSI(Lic)/D/SI Dated 31/10/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	-	30mt	MR
	• Gate width	-	Direct access from the road	MR
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	Not required	-	-
	• Pressurization	not required	-	-
	e. No. of continuous staircases to terrace	-	01	MR
	g. Width of Corridor			
	h. Door Size			
3	Compartmentation.	-	-	-

17/5

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Not required Not required Not required Not required Not required	— — — — —	— — — — —
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	— provided in Kitchen	— MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	water CO ₂ CO ₂ ABC type ISI marked	02 02 03	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	provided provided provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	Required	provided	MR
9	Public Address System.	Not required	—	—
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	— Required No false ceiling	— provided —	— MR —
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	Not Required	provided	MR

	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.	Not Required		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		450 LPM	provided	MR
		225 LPM		
		40mt	provided	MR
		Required	provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
		Required	provided	MR
		5000lb	provided	MR
		Required	provided	MR
15	Exit Signage.			
16	Provision of Lifts.	Not applicable		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 			

17/7

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	Required	provided	MR
18	Refuge Area.	Not applicable.		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room	Not required		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 CO ₂ type 4.5kg & 01 ABC type 5kg cap. fire extinguisher provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ^{renew} grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer


16/12/2011
Signature of the Inspecting Officer

Name

Name M.K. CHATTOPADHYAY

Designation

Designation ADO