

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/2011/ *School/3676*

Dated: *22/12/11*

FIRE SAFETY CERTIFICATE

Certified that Govt. Co-Ed. Sec. School Nehru Nagar, New Delhi comprised of ground and one upper floor Owned/Occupied by Govt. Co-Ed. Sec. School Nehru Nagar, New Delhi has complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and Rule 33 of the Delhi Fire Service Rules, 2010 and verified by concerned officer of Delhi Fire Service on 08.12.2011 in the presence of Shri Ram Dutt Sharma, Vice Principal/HOS of the school and that the building / premises is fit for occupancy class- B (Educational) with effect from *22/12/11* for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on *22/12/11* at New Delhi by


Chief Fire Officer
For Director
Delhi Fire Service

Copy To: -

1. Shri Ram Dutt Sharma, Vice Principal/HOS of the school
Govt. Co-Ed. Sec. School, Nehru Nagar, New Delhi
2. The Director of Education, Govt. of NCTD, Old Secretariat, Delhi.

Conditions for the validity of fire safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities, non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular intervals and record be maintained.

INSPECTION REPORT

1. Name & address of the building : Govt. Co-Education Sec. School, Nehru Nagar, ND.
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NIL Dated: _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 08-12-2011
7. Name of the Inspecting Officers : ADO RAGAN WADEHRA
8. Name and designation of officers from the building side : Shri Ram Dutt Sharma, Vice Principal
9. Year of Construction : 2003 C Ground and one upper floor
10. Applicant's letter No. : NIL

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 Meter	10 Meters	MR
	• Gate width	4 Meter	06 Meters	MR
	• Width of internal road	N/A	03 Meters	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	TWO	02 Nos.	MR
	• Basements	N/A	N/A	MR
	b. Width of staircases			
	• Upper Floors	1.5 Mts	1.5 Mts	MR
	• Basements	N/A	N/A	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	MR
	• Pressurization	N/A	N/A	MR
	e. No. of continuous staircases to terrace	ONE	TWO	MR
	g. Width of Corridor	1.5m	1.5m.	MR
	h. Door Size	1.0m	1.25m	MR
3	Compartmentation.	NOT REQUIRED		
	• Fire check door	/		
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	ISI marked	23 Nos. ABC - 15 CO2 - 08 ISI MARKED	MR MR MR
6	First-Aid Hose Reels.	NOT REQUIRED		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm		
7	Automatic fire detection and alarming system.	NOT REQUIRED		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8	MOEFA	NOT REQUIRED		MR
9	Public Address System.	NOT REQUIRED		MR
10	Automatic Sprinkler System.	NOT REQUIRED		MR
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants	NOT REQUIRED		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12	Yard Hydrants.	NOT REQUIRED		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put 			

	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply 	/	/	/
14	<ul style="list-style-type: none"> ➤ Auto Starting of pump Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	Not required	1,00,000 LTR.	MR
		/	/	/
			2000 x 3 = 6000	MR
15	Exit Signage.	REQUIRED	PROVIDED	MR
16	Provision of Lifts.	NOT REQUIRED		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	/	/	/
17	Standby power supply	NOT REQUIRED		
18	Refuge Area.	NOT REQUIRED		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	/	/	/
19	Fire Control Room	NOT REQUIRED		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	/	/	/
20	Special Fire Protection Systems for Protection of special Risks, if any:	/	/	/

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation


Do (South)


8/12/11

Signature of the Inspecting Officer

Name

Designation


RAJAN WADHANI
ASHI DIV Officer