

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS : DELHI FIRE SERVICE : \* NEW DELHI-110001

No : F.6/DFS/MS/2011/school/27

Dated : 03/01/12

To


The Officiating Principal,  
Guru Harikishan Public School,  
Hari Nagar,  
New Delhi-110064.

Ref No: No. GHPS/HN/1237/11-12 dated 31.10.2011.

FIRE SAFETY CERTIFICATE

Certified that the – Guru HariKishan Public School, Hari Nagar, New Delhi-110064. Comprised of - ground plus one upper floor only, owned/occupied by Guru Harikishan Public School, Hari Nagar, New Delhi-110064 has complied with the fire prevention and fire safety requirements in accordance with Director of Education letter No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officers concerned of fire Service on 21.11.2011 in the presence of - Sh. K.S. Grewal (Office Supdt.) and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on .....03/01/12.....at New Delhi.

  
Chief Fire Officer  
For Director  
Delhi Fire Service

Copy to:

1. The Director  
Govt. of N.C.T. of Delhi  
Directorate of Education,  
Old Secretariat, Delhi

gc  
mes

**INSPECTION REPORT**

1. Name & address of the building : Guru Hanuman Public School, Hari Nagar N.D.
2. Type of Occupancy : Education
3. Type of Case : New Case/Renewal
4. Details of previous NOC : Letter No. NIC Dated: \_\_\_\_\_
5. Fire Safety directives letter No : NIC
6. Date of inspection : 2/11/11
7. Name of the Inspecting Officers : D.O. H.L. Anjejs
8. Name and designation of officers from the building side : Sh. K.S. Grewal Officer Substn.
9. Year of Construction : —
10. Applicant's letter No. : G.H.P.S/H.N/1237/11-12 dt-31-10-11.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	R	12 Mtrs	MR
	• Gate width	R	3.55mtrs	MR
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>	MR	MR	
	a. Number of staircases	R	2 Nos	MR
	• Upper Floors	—	—	—
	• Basements	NIC	NIC	NIC
	b. Width of staircases	R	1852/1656mm	MR
	• Upper Floors	—	—	—
	• Basements	NIC	—	—
	c. Protection of exits	MR	MR	MR
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	2 Nos	MR
	g. Width of Corridor	R	2.30mtrs	—
	h. Door Size	R	1.20mtrs	—

3	<b>Compartmentation.</b>			
	• Fire check door	NR	NP	NMR
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	<b>Smoke Management System.</b>			
	• Basements	NR	NP	NMR
	• Upper floors	30 a/c per hour 12 a/c per hour	—	—
5	<b>Fire Extinguishers</b>			
	• Total numbers	R	P	NR
	• Types		12 Nos	—
	• IS marking	ISI marked	<del>ABC type</del> yes	—
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NR	NP	NMR
	• Length of hose reel hose	30 m	—	—
	• Nozzle diameter	5 mm	—	—
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NR	NP	NMR
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	<b>MOEFA</b>	—	—	—
9	<b>Public Address System.</b>	—	—	—
10	<b>Automatic Sprinkler System.</b>	—	—	—
	• Basement	—	—	—

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	—	—	—
11	<b>Internal Hydrants</b>	NR	NP	MMR
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	—	—	—
12	<b>Yard Hydrants.</b>	NR	NP	MMR
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	—	—	—
13	<b>Pumping Arrangements.</b>	NR	NP	MMR
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	—	—	—
14	<b>Captive Water Storage for fire fighting.</b>	NR	NP	MMR
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>	—	—	—

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
15	Exit Signage.	—	—	—
16	Provision of Lifts.	N.R	N.P	N.M.R
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	—
17	Standby power supply	N.R.	N.P	N.M.R
18	Refuge Area.	N.R	N.P	N.M.R
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
19	Fire Control Room	N.R	N.P.	N.M.R
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flw Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.P	N.M.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~..... Nil

(15)

*Handwritten signature*

Signature of the Inspecting Officer

Name *H. L. ANEJA*

Designation *Dir. Officer,*

Signature of the Inspecting Officer

Name */*

Designation