

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTER: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. *F6/DFSI/MS/2012/436*

Dated *08/02/12*

FIRE SAFETY CERTIFICATE

Certified that **two hostel buildings** (Boys & Girls) of Ch. Brahm Prakash Ayurved Charak Sansthan, comprised of ground + three upper floors located at Village Khera Dabar, Najafgarh New Delhi-110073, owned/occupied by **Ch. Brahm Prakash Ayurved Charak Sansthan** and Managed by DSIIDC have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 27/01/2012 in the presence of Sh. K.K. Sexana (A.E.E), Santosh Kumar, Surinder Kumar (J.E. Civil) & Sunil Kumar (J.E. Electt.) and that the building/premises is fit for occupancy class-group-A (Residential) w.e.f. the date of issue of this certificate for a period of **five years** in accordance with rule 36 unless renewed under rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under rule -38 of the Delhi Fire Service Rule, 2010 printed overleaf.

Issued on*08/02/12*..... at New Delhi.


Chief Fire Officer
for Director
Delhi Fire Service

9/2/12

Copy to:-

Sh. Sunil Kumar (Chief Project Manager),
DSIIDC, Udyog Sadan Building,
419, FIE, Patparganj Industrial Area,
New Delhi-110092.

(Ref No. DSIIDC/CMM-ED-VIII/2011/81 dated 07/12/11)

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Received Copy
Date 02/12
S.A.M (G) / AS 2200

INSPECTION REPORT

1. Name & address of the building : Ch. B. P. Ayurved Charak Sansthan, Khara Bahar, Anapipgaon, N.S. - 73.
2. Type of Occupancy : Residential (Hostel Boys & Girls)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. N/A Date _____
5. Fire Safety directives letter No : EG/DFS/ms/BP/2008/1435 dated 28.05.08
6. Date of inspection : 27.01.2012
7. Name of Inspecting Officer : D.O H.L. Aneja & A.D.O. P.S. Dahiya
8. Name and designation of officers : Sh. K.K. Saxena (A.E.E.), Santosh Kumar,
From the building side : Sh. Surinder Kumar (J.E Civil), Sunil Kumar (J.E Elect.)
9. Year of Construction : 2010 - 2011
10. Applicant's letter No. : DS/IDC/Cmm-ED-VIII/2011/81 dated 07.12.2011.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BRL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	15mtr	MR
	• Gate width	06mtr	06mtr	MR
	• Width of internal road	06mtr	06mtr	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Four	Four	MR
	• Upper Floors	- do -	- do -	MR
	• Basements	-	-	No Basement
	b. Width of staircases			
	• Upper Floor	125cm, Each	125cm each, 147cm each	MR
	• Basements	-	-	No Basement
	c. Protection of exits			
	• Fire check door	N/A	-	-
	• pressurization	N/A	-	-
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	-	Four	MR
	f. Door Size	-	140cm	MR
		-	88cm x 204cm	MR
3.	Compartmentation			
	• Fire check door	N/A	-	-
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	N/A	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		Natural Ventilation	MR


		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	12 Nos at each floor	Provided	MR
	• Types	WCo ₂ , Co ₂ , D.C.P	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Two	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	-	-	-
8.	MOEFA	-	-	-
9.	Public Address System	-	-	-
10.	Automatic Sprinkler System			
	• Basement	N/A	-	NO Basement
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100mm	MR
	• Number of hydrants per floor	-	Two	MR
	• Hose Box	-	Two	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	Four	MR
	• Hose Box	-	Four	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	2280 Lpm	2280 Lpm	MR
	➤ Head of Main pump	88 M	88 M	MR
	➤ Number of main pumps	Two	Two	MR
	➤ Jockey Pump out put	180 Lpm	180 Lpm	MR
	➤ Jockey pump head	40 M	40 M	MR
	➤ Standby Pump out put	2280 Lpm	2280 Lpm	MR
	➤ Standby Pump Head	88 M	88 M	MR
	➤ Auto Starting/Manual stopping	-	Both	MR

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	Provided	MR
		-	-	-
		-	-	-
		-	-	-
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50000 Ltr	50000 Ltr	MR
		Required	Provided	MR
		- do -	- do -	MR
		-	Provided	MR
		10000 Ltr	10000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		Required	Provided	MR
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The safety Certificate Only For Hostel (Boys & Girls) Block comprised of Ground floor plus three upper floors facilitated with two staircases in each Hostel Block.



Signature of Inspecting Officer

Name H. L. Aneja

Designation Divisional Officer



Signature of Inspecting Officer

Name P. S. Dahiya

Designation Asst. Divisional Officer.