

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2011 / GH/3545

Dated 15/12/11

FIRE SAFETY CERTIFICATE

Certified that the Mirja Guest House, located at 776, Motor Market, Jama Masjid Delhi-06 comprised of Ground + four upper floors having 08 Guest rooms (Ground floor is used for commercial purpose, First floor has 06 rooms, Second floor has 06 guest rooms, third floor has 02 guest rooms, Fourth floor is used for owner residence and terrace floor having open area Water tanks) was granted NOC by this department vide letter No F 6 / DFS / MS / GH / 2009 / 223 dated 27.01.2009. The premise was re-inspected by the officer concerned of this department on 30.11.2011 in the presence of Mr. S.R. Mirza found that the said Guest House have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" A-I with effect from 15/12/11 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/12/11..... at New Delhi

DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Comm. of Police (Lic) First Floor, Police Station Defence Colony, New Delhi.
2. The Owner, Mirja Guest House, located at 776, Motor Market, Jama Masjid Delhi-06

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Building covered under special area.
L. No.

old case

INSPECTION REPORT

1. Name & address of the building Mirza Givest House, 776, Motor Market, Jama Masjid, - Delhi-6.
2. Type of Occupancy Group-A-1, Residential.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/MS/DFS/GH/09/223 Dated: 27-1-2009
5. Fire Safety directives letter No F-6/MS/DFS/GH/01/1999 dt. 2nd 11/00 & F-6/MS/DFS/GH/01/292 dt. 19th 01.
6. Date of inspection 30-11-2011.
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers Prop. - S.R. Mirza,
from the building side :
9. Year of Construction 1960, (10 beds in 8 Guest Rooms at Ist, IInd & IIIrd floor.)
10. Applicant's letter No. :

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circulars G. H. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	N/A	9 mbs.	MR
	• Gate width	N/A	—	MR
	• Width of internal road	N/A	—	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	one	one	MR
	• Upper Floors	one	one	MR
	• Basements	N/A	NIL	N/A
	b. Width of staircases	80 cm.	80 cms	MR
	• Upper Floors	80 cms	80 cms	MR
	• Basements	N/A	NIL	
	c. Protection of exits			
	• Fire check door	N/A	N/A	
	• Pressurization	N/A		
	e. No. of continuous staircases to terrace	one	one	MR
	g. Width of Corridor	N/A	—	
	h. Door Size	N/A	—	

			N/A	
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A		
4	Smoke Management System.		N/A	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	6 W.CO2 = 3 ABE 5kg = 3 CO2 = 10 yes.	M R M R M R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one yes yes	M R M R M R
7	Automatic fire detection and alarming system.		N/A	
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A N/A N/A N/A N/A		
8	MOEFA	N/A	N/A	
9	Public Address System.	N/A	Provided.	
10	Automatic Sprinkler System.		N/A	
	<ul style="list-style-type: none"> • Basement 	N/A		

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	N/A		
		N/A		
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N/A	N/A	
		N/A		
		N/A		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	
		N/A		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	NIR	
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
			NIR	
			225 Lts/minute	
			40m	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 		NIR	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	Staircase.	Provided	
16	Provision of Lifts.		N/A	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		N/A	
18	Refuge Area.		N/A	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room		N/A	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:		Nil	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers...~~X~~.....

5

Signature of the Inspecting Officer

Name

Designation

D.O. (C/I) 41

Shyam Lal
02/12/2011

Signature of the Inspecting Officer

Name SHYAM LAL

Designation Assitt. Divn. officer.