

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI**

No: *F6/DFS/MS/School/2012/293*

Dated: *31/01/12*

FIRE SAFETY CERTIFICATE

Certified that the Bal Mandir Public School located at ground floor only Pushpa Bhawan, Ara Kashan Road, Paharganj, New Delhi-110055 owned/ occupied by Bal Mandir Public School, building comprised of ground plus three upper floors have complied with the prevention and fire safety requirements in accordance with the circular issued by the Director of Education dtd. 01-03-2011 and verified by the officer concerned of fire service on 20-01-2012 in the presence of Mrs. Indra Verma, Head Mistress of the school and that the building is fit for occupancy, class B "Educational Building" with effect from *..31.01.12.* for a period of three years, subject to conditions printed overleaf.

Issued *..31.01.12.* at New Delhi by.



CHIEF FIRE OFFICER
for DIRECTOR
DELHI FIRE SERVICE

Copy to :-



1. The Head Mistress, Bal Mandir Public School, Pushpa Bhawan, Ara Kashan Road, Paharganj, New Delhi-110055
2. The Director Education, MCD, Nigam Bhawan, Kashmiri Gate, Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Bal mandir public school, Pushpa Bhawan, Area Khasan Road, Paharganj, New Delhi - 110055.

2. Type of Occupancy : School Educational Building (Ground floor)

3. Type of Case : New Case/Renewal

4. Details of previous NOC : Letter No. - N.A - Dated: _____

5. Fire Safety directives letter No : As per circular no. F16/Estate/c.c./Fire safety/2011

6. Date of inspection : 20-01-2012 3298td 3398 dt 1-3-11

7. Name of the Inspecting Officers : D. S. Yadav A.D.O

8. Name and designation of officers from the building side : Mrs Indira Verma Headmistress.

9. Year of Construction : 1951

10. Applicant's letter No. : Letter no NIL dated 06-09-2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			<i>School running at Ground floor.</i>
	• Road width	<u>06 mtrs</u>	<u>06 mtrs</u>	<u>M.R</u>
	• Gate width	<u>Approachable</u>	<u>06 mtrs</u>	<u>M.R</u>
	• Width of internal road	<u>- N.A -</u>	<u>N.A</u>	<u>M.R</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>- N.A -</u>		
	• Basements			
	b. Width of staircases			
	• Upper Floors	<u>- N.A -</u>		
	• Basements			
	c. Protection of exits			
	• Fire check door	<u>- N.A -</u>		
	• Pressurization			
	e. No. of continuous staircases to terrace	<u>- N.A -</u>		
	g. Width of Corridor	<u>1.25 mtrs</u>	<u>1.25 mtrs</u>	<u>M.R.</u>
	h. Door Size	<u>1.25 mtrs</u>	<u>1.25 mtrs</u>	<u>M.R.</u>

contd: -

Balmandie Public School.
 Pushpa Bawan, Asakasha Road,
 Jalandhar, New Delhi-110055

3	Compartmentation.	- N.A -		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	- N.A -	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	Two A.B.C. and 5kg CO ₂ type 2.2kg	m.R. m.R. m.R.
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	- N.A -	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	- N.A -		
8	MOEFA	- N.A -		
9	Public Address System.	- N.A -		
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	- N.A -		

contd:-

Balmandi Public School,
 Pusepa Bawan, Asa Kasaan Road,
 Patel Gang, New Delhi-110055

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	N.A.		
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N.A.		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N.A.		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N.A.		
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	N.A.		

contd. :-

Balmardia Public School,
Pushpa Bhawan, Aashishan Road,
Pahar Ganj, New Delhi - 110051

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N.A.		
15	Exit Signage.	N.A.		
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N.A.		
17	Standby power supply	N.A.		
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N.A.		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N.A.		
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

contd. -

Balmandir Public School
Pushpa Bhawan, Aakashan Road,
Pahar Ganj, New Delhi - 110055.

(5)

Signature of the Inspecting Officer

D. S. Yadav
23-01-12
Signature of the Inspecting Officer

Name

Name *D. S. Yadav*

Designation

Designation *Assistant Divisional
Officer*