

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No. F6/DFS/ms/school/2012/301

Dated 01/02/12

**FIRE SAFETY CERTIFICATE**

Certified that the D.A.V. Public School, Sreshtha Vihar, Delhi -92. Comprised of basement ground plus three upper floors owned /occupied by D.A.V. Public School, Sreshtha Vihar, Delhi -92, have compiled with the fire prevention and fire safety requirements in the accordance with the rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of Delhi Fire Service on dated 12.01.12 in the presence of Mrs. Prem Lata Garg, Principal of the school and that the building is fit for occupancy class B 'Educational Building' with effect from 01/02/12 for a period of three years, subject to condition printed overleaf.

Issued on 01/02/12 at New Delhi by



Chief Fire Officer  
For Director  
Delhi Fire Service

92  
31.1.12

To,  
D.A.V. Public School,  
Sreshtha Vihar, Delhi -92

Copy to-  
The Joint Director of Education  
(Land & Estate)  
Directorate of Education,  
Lucknow Road, Delhi-54.

### INSPECTION REPORT

1. Name & address of the building : D.A.V. PUBLIC SCHOOL SRESHTHA VIHAR DELHI-92
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No.                      Dated:
5. Fire Safety directives letter No : DELHI FIRE SERVICE ACT -2007 and Rule 2010
6. Date of inspection : 12.1.2012
7. Name of the Inspecting Officers : ADO Suresh Singh
8. Name and designation of officers from the building side : Mrs Prem Lata Sang Principal
9. Year of Construction : 1989
10. Applicant's letter No. : 920/11 dated 20.12.2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	N/A Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 M	10 M	MIR
	• Gate width	4.5 M	6 M	MIR
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	5	1.25, 1.10, 1.50 1.50, 1.50 M	MIR
	• Upper Floors	5	1.25, 1.10, 1.50 1.50, 1.50	MIR
	• Basements	2 No	1.70, 1.20 M	MIR
	b. Width of staircases	1.50	1.70, 1.20 M	MIR
	• Upper Floors	1.50	1.25, 1.10, 1.50 1.50, 1.50 M	MIR
	• Basements	1.50	1.70, 1.20 M	MIR
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	2	2	MIR
	g. Width of Corridor	1.50 M	2.40	MIR
	h. Door Size	1 M	1 M	MIR

3	<b>Compartmentation.</b>			Provided	
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>				
4	<b>Smoke Management System.</b>	Required in Basement			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Exhaust fan		MIR
5	<b>Fire Extinguishers</b>	Required			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	55 No ISI marked	55 No CO2 ABC ISI		MIR MIR MIR
6	<b>First-Aid Hose Reels.</b>	Required			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	5 No on each floor 30 m 5 mm	12 No 30 m 5 mm		MIR MIR MIR
7	<b>Automatic fire detection and alarming system.</b>	N/A			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>				
8	<b>MOEFA</b>	N/A	Provided		MIR
9	<b>Public Address System.</b>	N/A	Provided	Yes	MIR
10	<b>Automatic Sprinkler System.</b>	Required			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Basement	Provided		MIR

	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	—	—	—
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm	100 mm	MIR
		3 No. each floor	3 No. each floor	MIR
		Provided near landing valve	Provided at each floor	MIR
12	<b>Yard Hydrants.</b>	N/A		
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	—	—	—
13	<b>Pumping Arrangements.</b>	<del>N/A</del> — Required —		
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		2 No 450 LPM	2 No 450 LPM	MR
		—	7.5	MIR
		7.5	7.5	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> </ul>	—	—	—
		—	—	—

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
15	Exit Signage.	—	Provided	NJR
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	—
17	Standby power supply	N/A	—	—
18	Refuge Area.	N/A		
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the D-Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~

Singh

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO

DO/LEAST

Signature of the Inspecting Officer

Name

Designation