

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : CONNAUGHT PLACE
NEW DELHI-110001

No: F.6/DFS/MS/2012/Schol/ 266

Dated: 30/01/12

To,

The Manager.
Laxmi Model School,
12 Block, Santoshi Matar Mandir
Tilak Nagar,
New Delhi.

Ref No. Nil dated 26.09.2011.

FIRE SAFETY CERTIFICATE

Certified that the Laxmi Model School located at 12 Block, Santosho Mata Mandir, (Near Community Hall) Tilak Nagar New Delhi-110018 comprised of Ground Floor owned as Mandir Shri Santoshi Mata Sabha (Regd.). Above school was issued NOC vide this office letter No. F.6/DFS/MS/2006/3327 dated 13.11.2006 owned/occupied by Mr. S.K.Bhatia have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 24.11.2011 in the presence of Mr. S.K. Bhatia and that the building/ premises is fit for occupancy class Educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on30/01/12.....at New Delhi by


Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

The Director
Govt. of N.C.T. of Delhi
Directorate of Education
Old secretariat
Delhi

spe
Mw

CF

INSPECTION REPORT

1. Name & address of the building : Caxmi Model School, 12 Block, Santham mata mandir, Tildak Nagar NO
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F&P/MS/2006/3327 Dated: 13.11.06
5. Fire Safety directives letter No : _____
6. Date of inspection : 24.11.11.
7. Name of the Inspecting Officers : DO. H. L. ANEJA
8. Name and designation of officers from the building side : Sh. S. K. Bhalis
9. Year of Construction : _____
10. Applicant's letter No. : NIL dt 26.9.2011.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	9mts	MR
	• Gate width	R	1.80mts	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NR	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	R	83cms	MR

(Being a old case)

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NR			
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	NR	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	R	ISI marked	P 2 Nos sand buckets ABE types Yes	MR MR MR
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NR	30 m 5 mm		
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NR			
8	MOEFA				
		NR			
9	Public Address System.				
		NR			
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement 	NR			

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	✓	✓	✓
11	Internal Hydrants	NR		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	✓	✓	✓
12	Yard Hydrants.	NR		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	✓	✓	✓
13	Pumping Arrangements.	NR		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	✓	✓	✓
14	Captive Water Storage for fire fighting.	NR		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	✓	✓	✓

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15	Exit Signage.	NR	—	—
16	Provision of Lifts.	NR	—	—
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17	Standby power supply	NR	—	—
18	Refuge Area.	NR	—	—
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19	Fire Control Room	NR	—	—
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue~~ shortcomings as noted at serial numbers..... NR

15

Signature of the Inspecting Officer
[Handwritten Signature]

Name *P. L. ANEJA*

Designation *Dir. Officer*

Signature of the Inspecting Officer

Name *[Handwritten Signature]*

Designation