

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001.

No. F6/DFS/MS/ EH/2012/227

Dated 24/01/12

FIRE SAFETY CERTIFICATE

Certified that **Mc Donald's family restaurant, at Eros Cinema building shop No. 2 & 3, GF, Jangpura Extn., New Delhi-110014** at Ground Floor Owned/Occupied by Mc Donald's family restaurant complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by concerned officer of Delhi Fire on 17.01.2012 in the presence of Mr. DN Thakur, Manager of the restaurant and that the premises is fit for occupancy class- "Assembly" with effect from ...24/01/12... for a period of **Three years**, subject to conditions as mentioned below.

Issued on24/01/12..... at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. Manager, Mc Donald's family restaurant, Eros Cinema building Shop No. 2 & 3, GF, Jangpura Extn., New Delhi-110014

Conditions for the validity of Fire Safety Certificate

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.dellhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building: MC DONALD'S Family restaurant
Eros cinema building shop No 2a3
415 Jangpura ext N-D-14
2. Type of Occupancy : Assembly (Restaurant) Ground floor only
3. Type of Case : NEW
4. Details of previous NOC : NIL
5. Fire Safety directives letter No : NIL Dated: NIL
6. Date of Inspection : 17/1/12
7. Name of the Inspecting Officers : Rajan Khandelwa
8. Name and designation of Officers : MR THAKUR
From the building side : _____
9. Year of Construction : _____
10. Applicant's letter No : NIL

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>15m</u>	<u>15m</u>	<u>MIR</u>
	• Gate width	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2	Number, Width, Type & Arrangement of Exits	<u>Ground floor.</u>		
	• Number of staircase	<u>NA</u>		
	➤ Upper Floors	/		
	➤ Basements	/		
	• Width of Staircases	<u>NA</u>		
	➤ Upper Floors	/		
	➤ Basements	/		
	• Protection of exits	<u>NA</u>		
	➤ Fire check door	/		
	➤ Pressurization	/		
	• No. of continuous staircases to terrace	<u>NA</u>	<u>NA</u>	<u>NA</u>
		<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Width of Corridor	<u>NA</u>	<u>NA</u>	<u>NA</u>
		<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Door Size	<u>NA</u>	<u>NA</u>	<u>NA</u>

3	Compartmentation	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 			
4	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	30 a/c Per hour	NA	NA
	<ul style="list-style-type: none"> • Upper Floors 	12 a/c Per hour	12 a/c Per hour	MIR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number 	one edd floor 300 gmt	6 NOS	MIR
	<ul style="list-style-type: none"> • Types 	ISI mark	3 ABC 3 CO ₂	MIR
	<ul style="list-style-type: none"> • IS marking 		YES	MIR
6	Firs-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total Number on each floor 	1	1	MIR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	30 m	MIR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	5mm	MIR
7	Automatic Fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke	Smoke	MIR
	<ul style="list-style-type: none"> • Location of Main Panel 	4F	4F	MIR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 			
	<ul style="list-style-type: none"> • Hooter's Location 	NA	NA	MIR
8	MOEFA	Provided		MIR
9	Public Address System	NA		NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MIR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	MIR
11	Internal Hydrants	NA		
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants	NA		
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 			

13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Number of main pump ➤ Discharge of main pump ➤ Head of main pump ➤ Jockey pump out put ➤ Jockey pump Head ➤ Standby pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto starting /manual 			
		2	2	MIR
		2280 LPM	2280 LPM	MIR
		70 mts	70 mts	MIR
		950 LPM	950 LPM	MIR
		70 mts	70 mts	MIR
		2280 LPM	2280 LPM	MIR
		70 mts	70 mts	MIR
		Auto	Auto	Auto
		required	Provided	MIR
		950 LPM	950 LPM	MIR
		45 mts	45 mts	MIR
		500 kVA	500 kVA	MIR
		Auto	Auto	MIR
14	Captive Water Storage for Fire Fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead tank capacity 			
		2,00,000 Lt	2,00,000 Lt	MIR
		Required	Provided	MIR
		Required	Provided	MIR
		Required	Provided	MIR
		40,000 Lt	40,000 Lt	MIR
		Required	Provided	MIR
15	Exit Signage			
		Required	Provided	MIR
16	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA		
17	Standby Power Supply			
18	Refuge Area			
	<ul style="list-style-type: none"> Total Area Location 	NA		
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery back up Building Floor Plans 	NA		

20	Special Fire Protection System for Protection of special risk, if any	Required	4 nos BSC fire ext	MIR
----	---	----------	--------------------	-----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue short-comings as noted~~ at serial number

DUCG

[Handwritten signature]
18/11/12

[Handwritten signature]
Signature of Inspecting Officer

Name **RASAN KADCHRA**

Designation: **Asst Dir ofes**