

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001.

No. F6/DFS/MS/ EH/ 2012/ 218

Dated 24/01/12

FIRE SAFETY CERTIFICATE

Certified that M/s **Mc Donald's family restaurant, TDI West side mall, Alankar Cinema, Lajpat Nagar- IV, New Delhi-110024** comprised of Ground Floor only Owned/Occupied by Mc Donald's family restaurant was granted NOC by this department vide letter No.F-6/DFS/MS/EH/2087/2734 dated 26.09.2008. The premises re-inspected by the officers concerned of Delhi Fire Service on 12/01/2012 in the presence of Mr. DN Thakur, Manager of the restaurant and that the building is fit for occupancy class- "Assembly" with effect from ...24/01/12... for a period of **Three years**, subject to conditions as mentioned below.

Issued on ...24/01/12... at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service



Copy to:

1. Manager, Mc Donald's family restaurant, TDI West side mall, Alankar Cinema, Lajpat Nagar- IV, New Delhi-110024

Conditions for the validity of Fire Safety Certificate

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building: MC DONALDS Family restaurant
TDI WEST SIDE MALL, ALANKAR CINEMA
LAJPAT NAGAR ND- 24
2. Type of Occupancy : ASSEMBLY
3. Type of Case : RENEWAL
4. Details of previous NOC F6 / DFS / MS / EH / 2008 / 2734 dt- 26 / 9 / 08
5. Fire Safety directives letter No : NIL Dated: NIL
6. Date of Inspection : 12 / 1 / 12
7. Name of the Inspecting Officers : RAJAN KHADHRA
8. Name and designation of Officers MR THAKUR
From the building side : _____
9. Year of Construction : _____
10. Applicant's letter No : NIL

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>15 mb</u>	<u>15MB</u>	<u>M/R</u>
	• Gate width	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2	Number, Width, Type & Arrangement of Exits	<u>Ground floor only</u>		
	• Number of staircase			
	➤ Upper Floors	<u>NA</u>	<u>NA</u>	<u>NA</u>
	➤ Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Width of Staircases			
	➤ Upper Floors	<u>NA</u>	<u>NA</u>	<u>NA</u>
	➤ Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Protection of exits		<u>NA</u>	
	➤ Fire check door	<u>/</u>	<u>/</u>	<u>/</u>
	➤ Pressurization	<u>/</u>	<u>/</u>	<u>/</u>
	• No. of continuous staircases to terrace		<u>NA</u>	
	• Width of Corridor	<u>/</u>	<u>/</u>	<u>/</u>
	• Door Size	<u>NA</u>	<u>NA</u>	<u>NA</u>

3	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 		NA	
4	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	30 a/c Per hour	NA	NA
	<ul style="list-style-type: none"> • Upper Floors 	12 a/c Per hour	Provided	MIR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number 	one ext Per 300sq mt	04	MIR
	<ul style="list-style-type: none"> • Types 	ISI mark	2 ABC 2 CO2	MIR
	<ul style="list-style-type: none"> • IS marking 		YES	MIR
6	Firs-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total Number on each floor 	1	1	MIR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	30m	MIR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	5mm	MIR
7	Automatic Fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke	Smoke	MIR
	<ul style="list-style-type: none"> • Location of Main Panel 	Ground floor	Ground floor	MIR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	625 KVA	625 KVA	MIR
	<ul style="list-style-type: none"> • Hooter's Location 	NA	NA	NA
8	MOEFA			
			Provided	MIR
9	Public Address System			
			NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required	Provided	MIR
		Required	Provided	MIR
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 		NA	
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 		NA	

13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	➤ Number of main pump	2	2	MIR
	➤ Discharge of main pump	2280 LPM	2280 LPM	MIR
	➤ Head of main pump	70 mH	70 mH	MIR
	➤ Jockey pump out put	450 LPM	950 LPM	MIR
	➤ Jockey pump Head	70 mH	70 mH	MIR
	➤ Standby pump out put	1	1	MIR
	➤ Standby Pump Head	70 mH	70 mH	MIR
	➤ Auto Starting/Manual	Auto	Auto	MIR
	➤ Pump House Access	Required	Provided	MIR
	• Terrace level			
	➤ Discharge of pump	1250 LPM	1250 LPM	MIR
	➤ Head of the pump	50 mH	50 mH	MIR
	➤ Power Supply	625 KVA	625 KVA	MIR
	➤ Auto starting /manual	Auto	Auto	MIR
14	Captive Water Storage for Fire Fighting			
	• underground tank capacity	1,00,000 Lts	1,35,000 Lts	MIR
	➤ Draw-off connection	Required	Provided	MIR
	➤ Fire service inlet	Required	Provided	MIR
	➤ Access to tank	Required	Provided	MIR
	• Overhead tank capacity	35,000 Lts	35,000 Lts	MIR
15	Exit Signage	Provided		MIR
16	Provision of Lifts	NA		
	• Pressurization of Lift Shaft	/	/	/
	• Pressurization of Lift lobby	/	/	/
	• Communication in lift Car	/	/	/
	• Fireman's Grounding Switch	/	/	/
	• Lift Signage	/	/	/
17	Standby Power Supply	625 KVA	625 KVA	MIR
18	Refuge Area	NA		
	• Total Area	/	/	/
	• Location	/	/	/
19	Fire Control Room	NA		
	• Detector System Panel	/	/	/
	• Flow Switch Panel	/	/	/
	• PA System Panel	/	/	/
	• Battery back up	/	/	/
	• Building Floor Plans	/	/	/


20	Special Fire Protection System for Protection of special risk, if any	Required	6 Nos of ABC fire et	MIR
----	---	----------	----------------------	-----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted~~ at serial number.....

Does


18/1/12


Signature of Inspecting Officer
Name **RAJAN MADHRA**
Designation: **Asst Div officer**