

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No. *F6/DFS/MS/EH/2012/170*

Dated : *19/01/12*

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of York Restaurant located at ground floor and Mezzanine floor at K-10-11, Connaught Circus, New Delhi - 110001 comprised of ground plus two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2008/1975 dated 15-07-2008. The premises was re-inspected by the officer concerned of this department on 13-01-2012 in the presence of Mr. Balbir Singh and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy with effect from2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service subject to conditions printed overleaf.

Issued *19/01/12* at New Delhi by.



CHIEF FIRE OFFICER
for DIRECTOR
DELHI FIRE SERVICE

18-1-12

Copy to :

1. Shri Surinder Pal Singh, M/s York Restaurant, K-10, Connaught Circus, New Delhi-110001
2. Shri P.K Sharma, Medical officer of Health, Health Department, Palika Kendra, Sansad Marg, New Delhi-110001

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : York Restaurant, 10-11, K block, Connaught Circus, New Delhi-11001.
2. Type of Occupancy : Restaurant
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. FE/DFS/MS/E.H/2008/1975 Dated: 15-07-2008
5. Fire Safety directives letter No : NIL
6. Date of inspection : 13-01-2012
7. Name of the Inspecting Officers : D.S. Yadav A.D.O
8. Name and designation of officers from the building side : Shri Balbir Singh
9. Year of Construction : prior to 1982.
10. Applicant's letter No. : NIL dated old case

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 M	more than 12 M	M.R
	• Gate width	1.25 M	1.25 M	M.R
	• Width of internal road	- N.A -	- N.A -	- N.A -
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two Exits	Mezanine floor 1st floor + 1 Exit	M.R
	• Basements	- N.A -	- N.A -	- N.A -
	b. Width of staircases			
	• Upper Floors	Two Exits	Mezanine floor 90 cm	M.R
	• Basements	- N.A -	- N.A -	- N.A -
	c. Protection of exits			
	• Fire check door	- N.A -		
	• Pressurization			
	e. No. of continuous staircases to terrace	- N.A -		
	g. Width of Corridor	- N.A -		
	h. Door Size	1.25 M	1.25 M	M.R

contd. -

Yock Restaurant,
K-10-11, canvaught eceval

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N. A		
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	- N. A - yes	- N. A - M.R.
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	Five CO2 Type = 2 Nos W. CO2 Type = 2 Nos A.B.C. Type = 1 No.	M.R. M.R. M.R.
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	one hose reel at ground floor yes	M.R. M.R. M.R.
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N. A		
8	MOEFA	yes	yes	M.R.
9	Public Address System.	N. A		
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N. A		

contd.

Yolk Restaurant 10-11, K block,
Connaught Circus, New Delhi-110029

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	yes	yes	M.R.
		- N.A -		
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	- N.A -		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- N.A -		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	- N.A -		
		450 LPM	450 LPM	M.R
		30 M	30 M	M.R
		yes	D.G. & BSES	M.R
		yes	yes	M.R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	- N.A -		
		- N.A -		

contd: -

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	yes	yes	M.R
		yes	yes	M.R
		5000 litres	5000 litres	M.R
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N.A		
17	Standby power supply	yes	D.G. set	M.R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N.A		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N.A		
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

contd. —

York Restaurant K 10-11, Connaught Circus,
New Delhi-110001

(5)

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

J. S. Yadav
16-01-2012

J. S. Yadav

*Assistant Divisional
Officer
(Control)*