

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**


No. F6/DFS/MS/2012/ *school/464*

Dated: *10/02/12*

FIRE SAFETY CERTIFICATE

Certified that the **MCD Primary School, G-Block, Krishna Market, Lajpat Nagar-I, New Delhi-110024** comprised of ground floor only **Owned/Occupied** by MCD Primary School has complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officers concerned of Delhi Fire Service on 18/01/2012 in the presence of Mrs. Sneh Lata, Principal of the school and that the building/premises is fit for occupancy class-B (Educational) with effect from 10/02/12 for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 10/02/12 at New Delhi by


Chief Fire Officer
For Director
Delhi Fire Service

Copy To: -

1. The Directorate of Education, *MCD Civic Centre*, Delhi.
2. Principal, MCD Primary School, G-Block, Krishna Market, Lajpat Nagar-I, New Delhi-110024


Conditions for the validity of fire safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

3	Compartmentation				NA
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 				
4	Smoke Management System				NA
	<ul style="list-style-type: none"> • Basements • Upper Floors 	30 a/c Per hour	12 a/c Per hour		
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	1 ext Per 300 sqm ISI mark	4 Nos 2 Nos ABC 2 Nos CO2	Yes	MIR MIR MIR
6	Firs-Aid Hose Reels				NA
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 		30 m 5mm		
7	Automatic fire detection and alarming system				NA
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 				
8	MOEFA				NA
9	Public Address System				NA
10	Automatic Sprinkler System				NA
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrants				NA
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 				
12	Yard Hydrants				NA
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 				


13 Pumping Arrangements

- Ground Level
 - Number of main pump
 - Discharge of main pump
 - Head of main pump
 - Jockey pump out put
 - Jockey pump Head
 - Standby pump out put
 - Standby Pump Head
 - Auto Starting/Manual
 - Pump House Access
- Terrace level
 - Discharge of pump
 - Head of the pump
 - Power Supply
 - Auto starting /manual



14 Captive Water Storage for Fire Fighting


- Underground tank capacity
 - Draw-off connection
 - Fire service inlet
 - Access to tank
- Overhead tank capacity



15 Exit Signage

16 Provision of Lifts


- Pressurization of Lift Shaft
- Pressurization of Lift lobby
- Communication in lift Car
- Fireman's Grounding Switch
- Lift Signage



17 Standby Power Supply


18 Refuge Area

- Total Area
- Location



19 Fire Control Room

- Detector System Panel
- Flow Switch Panel
- PA System Panel
- Battery back up
- Building Floor Plans



20	Special Fire Protection System for Protection of special risk, if any	N/A	N/A
----	---	-----	-----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted~~ at serial number.....




Signature of Inspecting Officer

Name **RAJAN MADHIRA**

Designation: **ASST DIR other**

DOCS


25/1/12