

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2011/3125

Dated: 23/11/2011

FIRE SAFETY CERTIFICATE

Certified that the Shop in Park located at Plot No.2, B-Block, Community Centre, Shalimar Bagh, New Delhi, comprised of basement+ground+three upper floors was granted NOC by this department vide letter No. F6/DFS/MS/2008/1470 dated 03/06/2008. The premises was re-inspected by the officers concerned of this department on 04/11/2011 in the presence of Mr. D.P Vashist (G.M.) of the shopping Mall and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for Class-F (Mercantile) occupancy with effect from 23/11/11..... for a period of three years subject to conditions printed below.

Issued on.....23/11/11.....at New Delhi by



Chief Fire Officer  
Delhi Fire Service

Copy to:  
Mr. D.P. Vashist (G.M.)  
Shop 'N' Park  
No.2, B-Block, Shalimar Bagh, New Delhi



Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

May Kindly peruse letter no. nil dated nil received from Authorized signatory regarding renewal of NOC in r/o Shopping Mall in the name & style Shop in Park Located at Plot No.2, B-Block, Community Centre, Shalimar Bagh, New Delhi, premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : Shop in Park Located at Plot No.2, B-Block, Community Centre, Shalimar Bagh, New Delhi
2. Type of Occupancy : Class -F (Mercantile)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2008/1470 dated 03/06/2008
5. Fire Safety directives letter No. : F6/DFS/MS/BP/2005/935
6. Date of inspection : 04.11.2011
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers  
From the building side : Mr. D.P. Vashist (G.M.)
9. Year of Construction : 2005-2006
10. Applicant's letter No. : nil

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12mtrs	24 mtr	M/R
	• Gate width	5 mtr	8.5 mtr	M/R
	• Width of internal road	6 mtr	6 mtr	M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	7	7	M.R
	• Basement	7	7	M.R

	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.5 mtr each	M.R.
	• Basement	1.5 mtr	1.5 mtr	M.R.
	c. Protection of exits			
	• Fire check door			
	• Pressurization	Required	Provided	M.R.
	d. No. of continuous staircases to terrace	Required	Provided	M.R.
		two	two	M.R.
	e. Width of Corridor	2.5 mtr	2.5 mtr	M.R.
	f. Door size	2 mtrs	2 mtr	M.R.
3.	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	Required	Provided	M.R.
	• Fire Rating of shaft door	2 hour	Provided	M.R.
	• Water Curtain	Required	Provided	M.R.
	• Fire Dampers	Required	Provided	M.R.
4.	<b>Smoke Management System.</b>			
	• Basements	Mechanical ventilation	Provided	M.R.
	• Upper floors	Required	Provided	M.R.
5.	<b>Fire Extinguishers</b>			
	• Total numbers	80	90	M.R.
	• Types	ABC & CO <sub>2</sub>	provided	M.R.
	• IS marking	ISI marks	provided	M.R.

<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	• Total numbers on each floor	5	5	M.R
	• Length of hose reel hose	30 m	provided	M.R
	• Nozzle diameter	5 mm	provided	M.R
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Heat type	Provided	M.R
	• Location of Main Panel	Ground floor	Provided	M.R
	• Location of Repeater Panel	Ground floor	Provided	M.R
	• Alternate source of power	Required	D.G. set 1250 KVA	M.R
	• Hooter's Location	Required all over building	Provided	M.R
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M.R
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	M.R
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	• Basement	Required	Provided	M.R.
	• Upper Floor	Required	Provided	M.R
	• Sprinkler above false ceiling	Required	Provided	M.R
<b>11.</b>	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	150 mm	provided	M.R
	• Number of hydrants per floor	5	5	M.R
	• Hose Box	5	5	M.R
<b>12.</b>	<b>Yard Hydrants.</b>			

	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	8	8	M.R
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	8	8	M.R
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	2850 LPM	2850 LPM	M.R
	➤ Head of Main pump	70 mtr	70 mtr	M.R
	➤ Number of main pumps	3	3	M.R
	➤ Jockey Pump out put	180 LPM	180 LPM	M.R
	➤ Jockey pump head	70 mtr	70 mtr	M.R
	➤ Standby pump out put	2850 LPM	2850 LPM	M.R
	➤ Standby pump Head	70 mtr	70 mtr	M.R
	➤ Auto Starting/Manual stopping	auto	auto	M.R
	➤ Pump Hose Access	Accessible	Accessible	M.R
	<b>Terrace level</b>			
	➤ Discharge of pump	N.A.	N.A.	M.R
	➤ Head of the pump	N.A.	N.A.	M.R
	➤ Power supply	N.A.	N.A.	M.R
	➤ Auto Starting of pump	N.A.	N.A.	M.R

	➤ Auto Starting of pump	N.A.	N.A	M.R
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	2 lakh	2 lakh	M.R
	➤ Draw -off connection	Required	Provided	M.R
	➤ Fire service inlet	Required	Provided	M.R
	➤ Access to tank	Required	Provided	M.R
	➤ Overhead Tank Capacity	30, 000 ltr	Provided	M.R
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	In Mall & Restaurant
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	Required	Provided	M.R
	• Pressurization of Lift lobby	Required	Provided	M.R
	• Communication In lift Car	Required	Provided	M.R
	• Fireman's Grounding Switch	Required	Provided	M.R
	• Lift Signage	Required	Provided	M.R
<b>17.</b>	<b>Standby power supply</b>	1250 KVA	Provided	M.R
<b>18.</b>	<b>Refuge Area</b>			
	➤ Total Area	N.R.	N.R.	M.R
	➤ Location	N.R.	N.R.	M.R
<b>19.</b>	<b>Fire Control Room</b>			
	➤ Detector System Panel	Required	Provided	M.R

	➤ Flow Switch Panel	Required	Provided	M.R ✓
	➤ PA system Panel	Required	Provided	M.R ✓
	➤ Batter backup	Required	Provided	M.R ✓
	➤ Building Floor plans	Required	Provided	M.R ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	M.R ✓

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/



Signature of the Inspection Officer

Signature of the Inspection Officer

Name SUNIL CHANDHARY

Name

Designation D.O.

Designation