

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2012/539

Dated: 17/02/2012

**FIRE SAFETY CERTIFICATE**

Certified that the **Berco's Restaurant** located at Plot no. 18, Pankaj Arcade, Road No.44, Rani Bagh Commercial Complex Pitam Pura, New Delhi-110034., comprised of ground + three upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2006/2662 dated 20/09/2006. The premises was re-inspected by the officers concerned of this department on 09/02/2012 in the presence of Sh. Naveet Gupta (Director) of the Restaurant and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for Class-D (Assembly) occupancy with effect from 17/02/12 for a period of three years subject to conditions printed below.

Issued on.....17/02/12.....at New Delhi by



Chief Fire Officer  
Delhi Fire Service



Copy to:  
Sh. Naveet Gupta (Director)  
**Berco's Restaurant**  
Plot no. 18, Pankaj Arcade, Road No.44,  
Rani Bagh Commercial Complex  
Pitam Pura, New Delhi-110034

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

May Kindly peruse letter no. nil dated 01-02-2012 received from Sh. Naveet Gupta (Director) for Holy Shrine Hotel Pvt. Ltd. regarding of NOC in r/o Berco's Restaurant located at Plot no. 18, Pankaj Arcade, Road No.44, Rani Bagh Commercial Complex Pitam Pura, New Delhi-110034. premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : **Berco's Restaurant** located at Plot no. 18, Pankaj Arcade, Road No.44, Rani Bagh Commercial Complex Pitam Pura, New Delhi-110034.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2006/2662 dated 20/09/2006
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 09/02/2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers  
 From the building side : Sh. Naveet Gupta (Director)  
 Year of Construction :
9. Applicant's letter No. : nil dated 01-02-2012

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12 mtrs	15 mtr	M/R
	• Gate width	4.5 mtr	Building is open on all side	M/R
	• Width of internal road	6 mtr	more than 6 mtr	M/R/
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	3	2	M.R
	• Upper Floors	3	2	M.R



	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	N.A.	Not applicable
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	Two 1.5 mtr	Two 1.5 mtr & one 1.25 mtr	M.R.
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	N.A.	Not applicable
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N/R	N/R	Not applicable
	d. No. of continuous staircases to terrace	2	3	M.R.
	e. Width of Corridor	2 mtr	Provided	M.R.
	f. Door size	2 mtr & 1.5 mtr	Provided	M.R.
3.	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	N/A	N/A	Not applicable
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	N/A	N/A	Not applicable
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N/A	N/A	Not applicable
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Provided	M.R.
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	4	10	M.R.

	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC & CO <sub>2</sub>	provided	M.R
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marks	provided	M.R
<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	1	Provided	M.R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	provided	M.R
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	provided	M.R
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke & Heat type	Provided	M.R
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Ground floor	Provided	M.R
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	M.R
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	Required	Provided	M.R
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M.R
<b>9.</b>	<b>Public Address System</b>	Required	Provided	M.R
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N/R	Provided	M.R
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	M.R
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 mm	provided	M.R

	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	1	Provided	M.R
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	1	Provided	M.R
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	N/R	N/R	Not applicable
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N/R	N/R	Not applicable
	➤ Head of Main pump	N/R	N/R	Not applicable
	➤ Number of main pumps	N/R	N/R	Not applicable
	➤ Jockey Pump out put	180 LPM	Provided	M.R
	➤ Jockey pump head	40 mtr	Provided	M.R
	➤ Standby pump out put	N/R	N/R	Not applicable
	➤ Standby pump Head	N/R	N/R	Not applicable
	➤ Auto Starting/Manual stopping	Required	Provided	M.R
	➤ Pump Hose Access	Required	Provided	M.R
	<b>Terrace level</b>			
	➤ Discharge of pump	450 LPM	Provided	M.R
	➤ Head of the pump	40 mtr	Provided	M.R

	➤ Power supply	Required	Provided	M.R
	➤ Auto Starting of pump	Required	Provided	M.R
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	N/R	N/R	Not applicable
	➤ Draw -off connection	N/R	N/R	Not applicable
	➤ Fire service inlet	N/R	N/R	Not applicable
	➤ Access to tank	N/R	N/R	Not applicable
	➤ Overhead Tank Capacity	10, 000 ltr	Provided	M.R
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M.R
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N/A	N/A	Not applicable
	• Pressurization of Lift lobby	N/A	N/A	Not applicable
	• Communication In lift Car	N/A	N/A	Not applicable
	• Fireman's Grounding Switch	N/A	N/A	Not applicable
	• Lift Signage	N/A	N/A	Not applicable
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M.R
<b>18.</b>	<b>Refuge Area</b>			
	➤ Total Area	N.R.	N.R.	Not applicable
	➤ Location	N.R.	N.R.	Not applicable
<b>19.</b>	<b>Fire Control Room</b>			



	➤ Detector System Panel	N.R.	N.R.	Not applicable ✓
	➤ Flow Switch Panel	N.R.	N.R.	Not applicable ✓
	➤ PA system Panel	N.R.	N.R.	Not applicable ✓
	➤ Batter backup	N.R.	N.R.	Not applicable ✓
	➤ Building Floor plans	N.R.	N.R.	Not applicable ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable ✓

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name SUNIL CHANDAN (R-1)

Name

Designation D.O -

Designation