

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. 26/DFS/MS/School/2012/698

Dated: 28/02/2012

FIRE SAFETY CERTIFICATE

Certified that the Ch Jaswant Lal Public School, is comprised of Ground + one upper floor located at Plot No 13, Street No 77, Punjabi Bagh West, New Delhi-110026 have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 02/02/2012 in the presence of Smt Arun Jangada, Principal and that the building the premises is fit for occupancy of Group Class B (Educational) with effect from 28/02/12 for a period of three years, subject to conditions mentioned below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement if any shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 28/02/12 at New Delhi by



Chief Fire Officer  
For Director  
Delhi Fire Service

Copy to:

1. Ch Jaswant Lal Public School, Plot No 13, Street No 77, Punjabi Bagh West, New Delhi-110026. (School ID-1515120)
2. The Director of Education, Old Secretariat, Delhi

dfc

(G+1)

INSPECTION REPORT

1. Name & address of the building : CH. Jaswant Lal Public School, Plot NO-13, Street NO-77, Punjabi Bagh west NO-26
2. Type of Occupancy : Educational
3. Type of Case :  New Case /  Renewal
4. Details of previous NOC : Letter No. — Dated: —
5. Fire Safety directives letter No : Dir of Education dtd 1/3/11
6. Date of inspection : 2/2/12
7. Name of the Inspecting Officers : ADD (MN) S. S. Tuli
8. Name and designation of officers from the building side : Smt Arun Jangada, Principal
9. Year of Construction : —
10. Applicant's letter No. : NO-NIL dtd 27/12/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6mtr	6mtr	m/R
	• Gate width	4.5m	4.5m	m/R
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	Two	Three of 110cm	m/R
	• Upper Floors	Two	— " —	— " —
	• Basements	—	—	—

	1.50 mtr & Two s/c of less width	Three s/c of 140 cms	m/r
b. Width of staircases	-	-	-
• Upper Floors	-	-	-
• Basements	-	-	-
c. Protection of exits	-	-	-
• Fire check door	-	-	-
• Pressurization	-	-	-
e. No. of continuous staircases to terrace	-	-	-
g. Width of Corridor	-	-	-
h. Door Size	1 mtr	1 mtr	m/r
3	NA -	-	-
• Fire check door	-	-	-
• Sealing of electrical shafts	-	-	-
• Fire Rating of shaft door	-	-	-
• Water Curtain	-	-	-
• Fire Dampers	-	-	-

### Smoke Management System.

	<ul style="list-style-type: none"> <li>Basements</li> </ul>	30 a/c per hour	—	—
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 a/c per hour	—	—
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>		08 nos	m/r
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ISI marked	ABC	m/r
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>		yes	m/r.
6	<b>First-Aid Hose Reels.</b>			
		N.A.	—	—
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	—	—
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	—	—
7	<b>Automatic fire detection and alarming system.</b>			
		N.A.		
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	—	—	—
8	<b>MOEFA</b>			
		N.A.	—	—
9	<b>Public Address System.</b>			
		N.A.	—	—

10 Automatic Sprinkler System.

		n/p	n/p	n/a
• Basement	-	-	-	-
• Upper Floor	-	-	-	-
• Sprinkler above false ceiling	-	-	-	-

11 Internal Hydrants

	N.A.			
• Size of riser/down-comer	-	-	-	-
• Number of hydrants per floor	-	-	-	-
• Hose Box	-	-	-	-

12 Yard Hydrants.

	N.A.			
• Total number of hydrants	-	-	-	-
• Hose Box	-	-	-	-

13 Pumping Arrangements.

	N.A.			
• Ground Level	-	-	-	-
➤ Discharge of main Pump	-	-	-	-
➤ Head of Main pump	-	-	-	-
➤ Number of main pumps	-	-	-	-
➤ Jockey Pump out put	-	-	-	-
➤ Jockey pump head	-	-	-	-
➤ Standby Pump out put	-	-	-	-
➤ Standby Pump Head	-	-	-	-

➤ Auto Starting/ Manual stopping	—	—	—
➤ Pump House Access	—	—	—
Terrace level	—	—	—
➤ Discharge of pump	—	—	—
➤ Head of the pump	—	—	—
➤ Power Supply	—	—	—
➤ Auto Starting of pump	—	—	—

14 **Captive Water Storage for fire fighting.**

NA

• Underground tank capacity	—	—	—
➤ Draw-off connection	—	—	—
➤ Fire service inlet	—	—	—
➤ Access to tank	—	—	—
• Overhead Tank capacity	—	—	—

15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>	N.A.		
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	<b>Standby power supply</b>	N.A.		
18	<b>Refuge Area.</b>	N.A.		
	➤ Total Area			
	➤ Location			
19	<b>Fire Control Room</b>	N.A.		
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	<b>Special Fire Protection Systems for</b>	N.A.		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DO (MN)

Signature of the Inspecting Officer

Name

Designation

*[Signature]*  
8/2/12  
SS Tuli  
ADO MN