

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS; DELHI FIRE SERVICE; CONNAUGHT PLACE; NEW DELHI

No F6/DFS/MS/school/2012/576

Dated 16/02/12

FIRE SAFETY CERTIFICATE

Certified that the Government Senior Secondary school comprised of ground plus Three upper floor only thus less than 9-meters located at Shahabad Daulatpur, New Delhi have complied with the fire prevention and fire safety requirements in accordance with the circular no.F.16/Estate/CC/Fire safety/2011/3298-3798 dated 01.3.11 issued by Director of Education and verified by the officer concerned of Fire Service on 28.1.12 in the presence of Vice Principal and the building/premises is fit for occupancy class Educational with effect from 16/02/12 for a period of Three Years, subject to conditions mentioned below.

Issue on 16/02/12 at New Delhi by


Chief Fire Officer
Delhi Fire Service

Vice Principal,

Government senior Secondary School,

Shahabad Daulatpur, New Delhi.

Copy to;-

Executive Engineer (E),

PWD EMD M-352

Dr BSA Hospital

Sec-6, Rohini, Delhi.

Conditions for validity of the certificate-

- All the fire safety means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering fire safety or means of escape facilities non functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record maintained.

INSPECTION REPORT

1. Name & address of the building : Govt Sr. Sec. School, Shrihalad Daulatpura, N. Delhi.
2. Type of Occupancy : Education (school) Bldg G + Three upper floors
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: - _____
5. Fire Safety directives letter No : _____
6. Date of inspection : _____
7. Name of the Inspecting Officers : DO Vipin Kental.
8. Name and designation of officers from the building side : vice principal
9. Year of Construction : 2008
10. Applicant's letter No. : 23(S)/PWD EMD. M-352/11-12/555 Dt 20/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement <small>Director of Education Circular M-1-3-11</small>	Provided at site	Remark MR/NM
1	Access to building			
	• Road width	9 mt	P	M/R
	• Gate width	5 mt	P	M/R
	• Width of internal road	6 mt	P	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	P	M/R
	• Basements	-	-	-
	b. Width of staircases			
	• Upper Floors	<small>one staircase of 1.50 mt. width distance between another staircase required.</small>	1.40 mt each.	M/R
	• Basements			
	c. Protection of exits			
	• Fire check door	N.A	-	-
	• Pressurization	N.A	-	-
	e. No. of continuous staircases to terrace			-
	g. Width of Corridor	N.A	-	-
	h. Door Size	1.00 mt	P	M/R

3	Compartmentation.	N/A		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	/		
4	Smoke Management System.	N/A		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	/	
5	Fire Extinguishers	N/A		
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Co2 type 1 DCP type 2kg / 300 m ² area ISI marked	water Co2 - 9kg Co2 type - 4.5kg P	
6	First-Aid Hose Reels.	N/A		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	R 30 m 5 mm	P P P	M/R -" -"
7	Automatic fire detection and alarming system.	N/A		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	/		
8	MOEFA	P	P	M/R
9	Public Address System.	N/A		
10	Automatic Sprinkler System.	N/A		
	<ul style="list-style-type: none"> • Basement 	/		

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A		
15	Exit Signage.	10.000hrs	10.000hrs	M/R
16	Provision of Lifts.	R	P	M/R
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A	
17	Standby power supply	R	P	M/R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:		NO special risks at present	

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Ventur
Signature of the Inspecting Officer

Name *MPIN KENTAL*

Designation *DO Mal.*

20/10

[Signature]
30/11