

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI – 110001**

No: F 6/DFS/MS/2011/ school/672

Dated:- 27/02/12

**FIRE SAFETY CERTIFICATE**

Certified that the MCD Primary (Boys) School Wazirabad Water works II  
Delhi 110054.....located at Wazirabad Water works, Delhi  
..... comprised of Ground floor only Cement bog Shed (7 Nos.)..... occupied  
by MCD Delhi..... was issued NOC vide this office letter  
No. F.6/DFS/MS/2008/870..... Dated: 28/3/2008. The premises was re-inspected by the  
officer concerned of this department on 2-3/1/12..... and observed that all the fire  
prevention and fire safety arrangements as provided in the premises found in good working  
condition. The premises have therefore, deemed complied with the requirement under Rule 33  
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class  
Educational.....with effect from 27/02/12 for a period of  
03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under  
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on 27/02/12 at New Delhi.

  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Director Edu (MCD)  
MCD, Nigan Behroun  
Kashmere Gate  
Delhi
2. The Principal  
MCD Pr- Boys School  
Wazirabad Water works  
Delhi 110054

9/2/12

1. All the means of escape shall be kept free of all type of obstruction all the time.
  2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants In case of emergency.
  3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
  4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
  5. Basement shall be used as per NBC.
  6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building : MCD Boys School, Wazirabad, Water works, Delhi
2. Type of Occupancy : Group Educational Semi permanent structure
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F.6/DFS/MS/2008/870 Dated: 28/3/08
5. Fire Safety directives letter No : F-16/Estate/CC/F safety/11/3298-3398 dt. 1-3-11
6. Date of inspection : 23-01-12
7. Name of the Inspecting Officers : A.D.O. SHYAM LAL
8. Name and designation of officers from the building side : Principal - H. Kumar
9. Year of Construction : 1961
10. Applicant's letter No. : NIL dt. 18-10-11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>6mtr.</u>	<u>MR</u>
	• Gate width	<u>- -</u>	<u>2.8 mtr</u>	<u>MR</u>
	• Width of internal road		<u>NA.</u>	
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>		<u>NA.</u>	
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>1 mtr.</u>	<u>1.7 mtr</u>	<u>MR</u>

3	<b>Compartmentation.</b>				
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			NR	
4	<b>Smoke Management System.</b>				
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour		NR	
5	<b>Fire Extinguishers</b>				
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	3  ISI marked	3 ABC Yes		MR
6	<b>First-Aid Hose Reels.</b>				
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	 30 m 5 mm		NR	
7	<b>Automatic fire detection and alarming system.</b>				
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			NR	
8	<b>MOEFA</b>				NR
9	<b>Public Address System.</b>				NR
10	<b>Automatic Sprinkler System.</b>				NR
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>				

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
11	<b>Internal Hydrants</b>			NR
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b>			NR
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>			NR
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
14	<b>Captive Water Storage for fire fighting.</b>			NR
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>			

Signature of the Inspecting Officer

Name

Designation

~~D.O. (M.W.)~~  
DCTO

beant  
6/24/2

Shyam Lal  
24/11/2012

Signature of the Inspecting Officer

Name

Designation Assit. Divn. officer

SHYAM LAL