

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2012/639

Dated: 24/02/2012

FIRE SAFETY CERTIFICATE

Certified that the R S Sec. Public School, is comprised of Ground + one upper floor building thus below 09 mtrs, located at RZ/D-66, Nihal Vihar, New Delhi-110041 have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 07/02/2012 in the presence of Mrs Ritu Mahendru, Chairman and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 24/02/12 for a period of three years, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in


Issued on 24/02/12 at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. Mrs. Ritu Mahendru, Chairman, R S Sec. Public School, RZ/D-66, Nihal Vihar, New Delhi-110041
2. The Director of Education, Old Secretariat, Delhi

072


INSPECTION REPORT

1. Name & address of the building : R.S. Sec. Public School, RZ/D-66, Nihal vihar, New Delhi-41
2. Type of Occupancy : Educational
3. Type of Case : New Case / ~~Renewal~~
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : As per Dir of Edu Lttrdtd 1/3/11
6. Date of inspection : 07/02/12
7. Name of the Inspecting Officers : ADO SSTuli
8. Name and designation of officers
from the building side : Mrs Ritu Mehendru, Chairman
9. Year of Construction : -
10. Applicant's letter No. : Nil dtd 12/12/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building	<u>Regd</u>	<u>Provided</u>	<u>m/r</u>
	• Road width	<u>-</u>	<u>-</u>	<u>-</u>
	• Gate width	<u>-</u>	<u>-</u>	<u>-</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>Two</u>	<u>Provided</u>	<u>m/r</u>
	• Upper Floors	<u>Two</u>	<u>- " -</u>	<u>- " -</u>

<p>b. Width of staircases</p> <ul style="list-style-type: none"> • Upper Floors • Basements <p>c. Protection of exits</p> <ul style="list-style-type: none"> • Fire check door • Pressurization <p>e. No. of continuous staircases to terrace</p> <p>g. Width of Corridor</p> <p>h. Door Size</p>	<p>one of 1.5 mtr</p> <p>- " -</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>1 mtr</p>	<p>1.5M & 80cms (iron staircase)</p> <p>- " -</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>1 mtr</p>	<p>M/R</p> <p>- " -</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>M/R</p>
<p>3 Compartmentation.</p>	<p>NR</p>	<p>NP</p>	<p>NA</p>
<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p>	<p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p>	<p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p>

Smoke Management System.

	<ul style="list-style-type: none"> Basements 	30 a/c per hour	—	—
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	—	—
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	ISI marked	05 ABC	M/R
	<ul style="list-style-type: none"> Types 		ABC Type	M/R
	<ul style="list-style-type: none"> IS marking 		yes	yes
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	30 m	—	—
	<ul style="list-style-type: none"> Length of hose reel hose 		—	—
	<ul style="list-style-type: none"> Nozzle diameter 		5 mm	—
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	—	—	—
	<ul style="list-style-type: none"> Location of Main Panel 	—	—	—
	<ul style="list-style-type: none"> Location of Repeater Panel 	—	—	—
	<ul style="list-style-type: none"> Alternate source of power 	—	—	—
	<ul style="list-style-type: none"> Hooters' Location 	—	—	—
8	MOEFA			
		—	—	—
9	Public Address System.			
		—	—	—

10	Automatic Sprinkler System.	N/R	N/P	N/A
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	<ul style="list-style-type: none"> — — — 	<ul style="list-style-type: none"> — — — 	<ul style="list-style-type: none"> — — —
11	Internal Hydrants	—	—	—
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	<ul style="list-style-type: none"> — — — 	<ul style="list-style-type: none"> — — — 	<ul style="list-style-type: none"> — — —
12	Yard Hydrants.	—	—	—
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	<ul style="list-style-type: none"> — — 	<ul style="list-style-type: none"> — — 	<ul style="list-style-type: none"> — —
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head 	<ul style="list-style-type: none"> — — — — — — — 	<ul style="list-style-type: none"> — — — — — — — 	<ul style="list-style-type: none"> — — — — — — —

➤ Auto Starting/ Manual stopping	-	-	-
➤ Pump House Access	-	-	-
Terrace level			
➤ Discharge of pump			
➤ Head of the pump			
➤ Power Supply	-	-	-
➤ Auto Starting of pump	-	-	-

14 Captive Water Storage for fire fighting.

• Underground tank capacity	-	-	-
➤ Draw-off connection	-	-	-
➤ Fire service inlet	-	-	-
➤ Access to tank	-	-	-
• Overhead Tank capacity	-	-	-

15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DO (MNS)
9/2/12

Signature of the Inspecting Officer

Name

Designation

8/2/12
S S Tuli
ADO (MNS)