

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001


No F6/DFS/MS/mcl/2012/628

Dated 24/02/12

FIRE SAFETY CERTIFICATE

Certified that the M/S Uttam Toyota located at 94, F.I.E. Patpar Ganj Industrial Area Delhi. which comprises of basement, ground & first floor was granted NOC by this deptt. vide letter No. F6 / DFS / MS / BP / 98 / 1564 dated 13-8-1998. The premises was re-inspected by the officer concerned of this deptt. on 6-2-2012 in the presence of Mr. Yadav G.M. and found that the bldg. have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy with effect from 24-02-2012 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/02/12 at New Delhi.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Recd.
23.2.2012

Copy to :-

1. General Manager

M/S Uttam Toyota

94, F.I.E. Patpar Ganj,

Industrial Area, Delhi.

2. The Administrative Officer (FL)

Municipal Corporation of Delhi

Factory Licensing Deptt.,

Nigam Bhawan Kashmere Gate,

Delhi.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basements shall be used as per BBL
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

INSPECTION REPORT

1. Name & address of the building : Uttam Toyota, 94, F.I.E. Patparganj, Delhi
2. Type of Occupancy : Indl.
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F6/ms/DFS/DD/98/1564 Dated: 13.8.98
5. Fire Safety directives letter No : _____
6. Date of inspection : 06.02.2012
7. Name of the Inspecting Officers : Guramkh Singh.
8. Name and designation of officers from the building side : Mr. Yadav Gm. & other staff
9. Year of Construction : 1998
10. Applicant's letter No. : NIL dt. 17.1.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Existing Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	30'	60'	MR
	• Gate width	4.5 mtrs	5.0 mtrs	- -
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	one	one	MR
	• Upper Floors	one	one	- -
	• Basements	one	one	- -
	b. Width of staircases			
	• Upper Floors	1.10 mtrs	1.10 mtrs	- -
	• Basements	1.10 mtrs	1.10 mtrs	- -
	c. Protection of exits	NA	NA	—
	• Fire check door	/	/	
	• Pressurization	/	/	
	e. No. of continuous staircases to terrace	one	one	MR
	g. Width of Corridor	NA	NA	—
	h. Door Size	1.0 mtrs	1.2 mtrs	MR

3	Compartmentation.	NA	NA	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	/	/	
4	Smoke Management System.	NA	NA	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	/	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	4 Nos. CO ₂ , ABC, NCO ₂ ISI marked	10 Nos. CO ₂ ABC, WCO ₂ Yes	MR. /
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 m 5 mm	one no. 30 meter 5 mm	MR -11- -11-
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA /	Provided. /	MR
8	MOEFA	NA	Provided.	MR
9	Public Address System.	NA	Provided.	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	NA.	Provided.	MR

	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	—
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	—
11	Internal Hydrants	NA	Provided.	
	<ul style="list-style-type: none"> • Size of riser/down-comer 	/	4" dia	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	/	one no.	— 11 —
	<ul style="list-style-type: none"> • Hose Box 	/	one no.	— 11 —
12	Yard Hydrants.	NA	NA	
	<ul style="list-style-type: none"> • Total number of hydrants 	/	/	—
	<ul style="list-style-type: none"> • Hose Box 	/	/	—
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level 	NA		—
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	/		
	<ul style="list-style-type: none"> ➤ Head of Main pump 	/		/
	<ul style="list-style-type: none"> ➤ Number of main pumps 	/		
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	/		
	<ul style="list-style-type: none"> ➤ Jockey pump head 	/		
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	/		
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	/		
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	/		
	<ul style="list-style-type: none"> • Pump House Access 	/		/
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 LPM	900 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	35 mts	38 mts	MR
	<ul style="list-style-type: none"> ➤ Power Supply 	Provided	Provided.	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NA	Yes	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	NA	NA	—
	<ul style="list-style-type: none"> ➤ Draw-off connection 	/	/	—

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	/	/	
		5,000 lbs	5000 lbs.	MR
		Regol.	Provided	MR
15	Exit Signage.	NA	NA	
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	/	/	
		Regol.	Provided	MR
17	Standby power supply			
18	Refuge Area.	N-A	NA	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	/	/	
19	Fire Control Room	NA	NA	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	/	/	
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~

Gurmand
16/2/12

Signature of the Inspecting Officer

Name *Gurmandh Singh*

Designation *ADD (LH)*

[Signature]

Signature of the Inspecting Officer

Name

Designation

DO (E)

Submitted for approval please.