

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F6/DFS/MS/ *school/2012/701*

Dated: *28/02/12*

**FIRE SAFETY CERTIFICATE**

Certified that **Uttaranchal Public School, 3312/72-73, Molarband Extn. , Badarpur, New Delhi-110044**, comprised of ground plus one upper floor **Owned/Occupied by** Uttaranchal Public School, has complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire Service on 03/02/2012 in the presence of Shri Avani Kumar Sharma, Manager of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from *28/02/12* for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on *28/02/12* at New Delhi by

  
Chief Fire Officer  
For Director  
Delhi Fire Service

**Copy To: -**

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi. *o/c MUR*
2. The Manager, Uttaranchal Public School,  
3312/72-73, Molarband Extn, Badarpur, New Delhi-110044

**Conditions for the validity of fire safety Certificate**

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name and address of the building: Uttaranchal Public School  
: 3312/72-73, Malabar Band Extn Badarpur N.D 110044
2. Type of Occupancy : Edeuation
3. Type of Case : New
4. Details of previous NOC : nil
5. Fire Safety directives letter No : nil Dated: \_\_\_\_\_
6. Date of Inspection : 8/2/12
7. Name of the Inspecting Officers : Rajan wadhwa ADO / m. Road
8. Name and designation of Officers  
From the building side : Shri. Ayami Kumar Sharma (Manager)
9. Year of Construction : Ground and one upper floor
10. Applicant's letter No : nil

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	15Mts	15Mts	MIR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	• Number of staircase			
	➤ Upper Floors	2	2	MIR
	➤ Basements	NA	NA	NA
	• Width of Staircases			
	➤ Upper Floors	1.50m	① 1.10 m. ② 0.80 m	old case / building MIR
	➤ Basements	NA	NA	NA
	• Protection of exits		NA	
	➤ Fire check door	/ / /		
	➤ Pressurization	/ / /		
	• No. of continuous staircases to terrace	1	1	MIR
	• Width of Corridor	/ / /		
	• Door Size	/ / /		

3	Compartmentation			NA
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>			
4	Smoke Management System			NA
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c Per hour		
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	12 a/c Per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total Number</li> </ul>	1 ext 300m <sup>2</sup>	05 NOS.	MIR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ISI mark	ABC	MIR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>		YES	YES
6	Firs-Aid Hose Reels			NA
	<ul style="list-style-type: none"> <li>• Total Number on each floor</li> </ul>			
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m		
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5mm		
7	Automatic Fire detection and alarming system			NA
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's Location</li> </ul>			
8	MOEFA			NA
9	Public Address System			NA
10	Automatic Sprinkler System			NA
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
11	Internal Hydrants			NA
	<ul style="list-style-type: none"> <li>• Size of riser/down comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	Yard Hydrants			NA
	<ul style="list-style-type: none"> <li>• Total Number of hydrants</li> <li>• Hose Box</li> </ul>			



Special Fire Protection System for  
Protection of special risk, if any


NA

NA

NA

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / issue shortcomings as noted at serial number.....



Signature of Inspecting Officer  
Name : RAJAN WADEHRA  
Designation: ASST. DIV. OFFICER

DO (South)

