

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/015/school/2012/537

Dated: 17 / 02 / 2012


FIRE SAFETY CERTIFICATE

Certified that the **Dropati Davi Memorial Educational Society** is comprised of **basement, Ground + 02 upper floor building thus below 09 mtrs, located at plot No. NS-2,RP Block Pitampura, Delhi-110034.**, have complied with the fire prevention and fire safety requirements in accordance with the **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 09/02/2012** in the presence of **Parmod Mittal (Chairman)** and that the building / premises is fit for occupancy of **Group B Educational Building Class Sub Div. B-1 (Nursury School)** with effect from 17 / 02 / 2012 for a period of **three years**, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements, means of escape facilities shall be maintained in good working condition at all times. Any lapse rendering fire safety systems or means of escape facilities no-functional shall be responsibility of the management.
2. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate shall be null and void.
3. The staff shall be trained for operating fire fighting systems and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 17/02/12 at New Delhi by


16/2
Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. Sh. Parmod Mittal (Chairman),
Smt. Dropati Davi Memorial Educational Society on plot No. NS-2,RP
Block Pitampura, Delhi-110034.
2. The Director of Education, Old Secretariat, Delhi

May kindly peruse letter no. nil dated 09-01-2012 received from the authorized signatory Smt. Dropati Davi Memorial Educational Society, regarding issuance of NOC r/o Smt. Dropati Davi Memorial Educational Society on located at plot No. NS-2,RP Block Pitampura, Delhi-110034. from fire safety point of view. It was observed that the society building is comprised of basement, ground+ two upper floor. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa

1. Name & address of the building : Smt. Dropati Davi Memorial Educational Society on plot No. NS-2,RP Block Pitampura, Delhi-110034.
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : N.A.
5. Fire Safety directives letter No. : F-6/DFS/MS/2011/BP/335 dated 18-2-2011
6. Date of inspection : 09/02/2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
From the building side : *Mr. Parmod Mittal (Chairman)*
8. Year of Construction : 2011-2012
9. Applicant's letter No. : nil dated 9-1-12

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 mtrs	23.5 mtrs ✓	M/R
	• Gate width	4.5mtrs	5 mtrs ✓	M/R
	• Width of internal road	6 mtr & 3 mtr	6 mtr front 3 mtr set back areas	M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	provided	M/R
	• Upper Floors	2	provided	M/R
	• Basement	2	Provided	M/R

	b. Width of staircases			
	• Upper Floors	1.5 mtr & 1.25 mtr	provided	M/R, as per section plan
	• Basement	1.5 mtr & 1.25 mtr	Provided	M/R
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N/R	N/R	Not applicable
	d. No. of continuous staircases to terrace	2	Provided	M/R
	e. Width of Corridor	Required 1.5 mtr	Provided	M/R, as per section plan
f. Door size	1.25 mtr	Provided	M/R	
3.	Compartmentation.			
	• Fire check door	Required	Provided	M/R
	• Sealing of electrical shafts	Required	Provided	M/R
	• Fire Rating of shaft door	1 hr.	Provided	M/R
	• Water Curtain	N/R	N/R	Not applicable
	• Fire Dampers	N/R	N/R	Not applicable
4.	Smoke Management System.			
	• Basements	Required	Provided	M/R
	• Upper floors	N/R	N/R	Not applicable
5.	Fire Extinguishers			
	• Total numbers	12 nos	15	M/R
	• Types	ABC type & CO ² type	Provided	M/R
	• IS marking	ISI marked required	provided	M/R
6.	First-Aid Hose Rees.			

	<ul style="list-style-type: none"> Total numbers on each floor 	2	Provided	M/R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	M/R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm required	Provided	M/R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Location of Main Panel 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Alternate source of power 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Hooter's Location 	N/R	N/R	Not applicable
8.	MOEFA	Required	Provided	M/R
9.	Public Address System.	Required	Provided	M/R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M/R
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M/R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	M/R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	M/R
	<ul style="list-style-type: none"> Number of hydrants per floor 	1	Provided	M/R
	<ul style="list-style-type: none"> Hose Box 	1	Provided	M/R
12.	Yard Hydrants.	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Total number of hydrants 	N/R	N/R	Not applicable

	<ul style="list-style-type: none"> Hose Box 	N/R	N/R	Not applicable
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N/R	N/R	Not applicable
	➤ Head of Main pump	N/R	N/R	Not applicable
	➤ Number of main pumps	N/R	N/R	Not applicable
	➤ Jockey Pump out put	N/R	N/R	Not applicable
	➤ Jockey pump head	N/R	N/R	Not applicable
	➤ Standby pump out put	N/R	N/R	Not applicable
	➤ Standby pump Head	N/R	N/R	Not applicable
	➤ Auto Starting/Manual stopping	N/R	N/R	Not applicable
	➤ Pump Hose Access	N/R	N/R	Not applicable
	Terrace level			
	➤ Discharge of pump	One Pump 450 LPM on terrace	Provided	M/R
	➤ Head of the pump	40 mtr	Provided	M/R
	➤ Power supply	N/R	N/R	Not applicable
	➤ Auto Starting of pump	N/R	N/R	Not applicable
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N/R	N/R	Not applicable
	➤ Fire service inlet	N/R	N/R	Not applicable
	➤ Access to tank	N/R	N/R	Not applicable
	➤ Overhead Tank Capacity	10,00 ltrs	provided	M/R

15	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> • Communication In lift Car 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> • Lift Signage 	N/R	N/R	Not applicable
17.	Standby power supply	N/R	N/R	Not applicable
18.	Refuge Area	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> ➤ Total Area 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> ➤ Location 	N/R	N/R	Not applicable
19.	Fire Control Room		N/P	
	<ul style="list-style-type: none"> ➤ Detector System Panel 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> ➤ Flow Switch Panel 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> ➤ PA system Panel 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> ➤ Batter backup 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> ➤ Building Floor plans 	N/R	N/R	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/R	N/R	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/



Signature of the Inspection Officer

Signature of the Inspection Officer

Name SUNIL (अनुमोदक-)

Name

Designation D.O.

Designation

~~Dy. CFO~~ ~~CFO~~ ~~14/2~~
~~14/2~~

~~FT~~ ~~15/2~~
FT 14/2

FT letter is put up for signature P.S.

~~CFO~~ ~~16/2~~

~~16/2~~

MS