

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F61DFS/MS/INDU/2011/3702

Dated: 26/12/2011

FIRE SAFETY CERTIFICATE

Certified that the Plot no. K-32, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041., comprised of basement, ground floor and first floor was granted NOC by this department vide letter No. F F-6/DFS/MS/BP/89/1010 dated 19.09.1989. The premises was re-inspected by the officers concerned of this department on 12/12/2011 in the presence of Mr. Shori Lal (Manager) of the factory and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class-G (G-1) Industrial** occupancy with effect from26/12/11..... for a period of three years subject to conditions printed below.

Issued on.....26/12/2011.....at New Delhi by


Director
Delhi Fire Service

Copy to:
Mr. Shori Lal (Manager)
Plot no. K-32, Udyog Nagar,
Industrial Area, Rohtak Road, New Delhi-110041.

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated nil received from Mr. Shori Lal, regarding of NOC in r/o Plot no. K-32, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041. premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa

1. Name & address of the building : Plot no. K-32, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041.
2. Type of Occupancy : Class-G (G1) Industrial
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/BP/89/1010 dated 19.09.1989
5. Fire Safety directives letter No. : F6/DFS/MS/BP/87/1918 dated 14-11-1987
6. Date of inspection : 18-10-2011
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
8. Name and designation of officers
From the building side : Mr. Shori Lal
9. Year of Construction : 1999-1989
10. Applicant's letter No. : nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	15mtr.	M.R.
	• Gate width	4.5 mtr	5 mtr	M.R.
	• Width of internal road	3 mtr	Provided	M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	two	M.R.
	• Upper Floors	one, as per sanction plan	1	M.R.
	• Basement	Two, as per sanction plan	two	M.R.

	b. Width of staircases				
		• Upper Floors	As per sanction plan 1.20 mtr	1.20 mtr	M.R.
		• Basement	As per sanction plan 1.2 mtr	1.20 mtr	M.R.
	c. Protection of exits				
		• Fire check door	Required	Provided	M.R.
		• Pressurization	N.R.	N.R.	
	d. No. of continuous staircases to terrace		As per sanction plan	One	M.R.
			N.R. Halls only	N.R. halls only	
e. Width of Corridor					
f. Door size		1 mtrs	1 mtrs	M.R.	
3.	Compartmentation.				
	• Fire check door	Required	Provided	M.R.	
	• Sealing of electrical shafts	N.A	N.R.		
	• Fire Rating of shaft door	N.A	N.R.		
	• Water Curtain	N.R.	N.R.		
	• Fire Dampers	N.A.	N.R.		
4.	Smoke Management System.				
	• Basements	Required	Exhaust fan provided	M.R	
	• Upper floors	N.R.	N.R		
5.	Fire Extinguishers				
	• Total numbers	06	10	M.R	
	• Types	ABC & CO ₂ type	provided	M.R	

	• ISI marking	ISI marked	provided	M.R
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	1	1	M.R
	• Length of hose reel hose	30 m	provided	M.R
	• Nozzle diameter	5 mm	provided	M.R
7.	Automatic fire detection and alarming system.			
	• Type of detectors	N.R	N.R	—
	• Location of Main Panel	N.R	N.R	—
	• Location of Repeater Panel	N.R	N.R	—
	• Alternate source of power	N.R	N.R	—
	• Hooter's Location	N.R	N.R	—
8.	MOEFA	N.R	N.R.	—
9.	Public Address System.	N.R.	N.R.	—
10.	Automatic Sprinkler system			
	• Basement	N.R.	N.R.	—
	• Upper Floor	N.R	N.R.	—
	• Sprinkler above false ceiling	N.R.	N.R.	—
11.	Internal Hydrants			
	• Size of riser/down-comer	N.R.	N.P.	—
	• Number of hydrants per floor	N.R.	N.P.	—

	• Hose Box	N.R.	N.P.	✓
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	✓
	• Hose Box	N.R.	N.R.	✓
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	✓
	➤ Head of Main pump	N.R.	N.R.	✓
	➤ Number of main pumps	N.R.	N.R.	✓
	➤ Jockey Pump out put	N.R.	N.R.	✓
	➤ Jockey pump head	N.R.	N.R.	✓
	➤ Standby pump out put	N.R.	N.R.	✓
	➤ Standby pump Head	N.R.	N.R.	✓
	➤ Auto Starting/Manual stopping	N.R.	N.R.	✓
	➤ Pump Hose Access	N.R.	N.R.	✓
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R
	➤ Head of the pump	30 mtr	provided	M.R
	➤ Power supply	Required	100 KVA	M.R
	➤ Auto Starting of pump	Manual	Provided	M.R

14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	25,000	10,000	M.R.
	➤ Draw -off connection	required	provided	M.R.
	➤ Fire service inlet	required	provided	M.R.
	➤ Access to tank	required	provided	M.R.
	➤ Overhead Tank Capacity	50,000 ltr	10,000	M.R.
15	Exit Signage.	N.R.	N.R.	
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A.	N.R.	—
	• Pressurization of Lift lobby	N.A.	N.R.	—
	• Communication In lift Car	N.A.	N.R.	—
	• Fireman's Grounding Switch	N.A.	N.R.	—
	• Lift Signage	N.A.	N.R.	—
17.	Standby power supply	N.R.	100 K.V.A.	M.R.
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	—
	➤ Location	N.R.	N.R.	—
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	—

	➤ Flow Switch Panel	N.R.	N.R.	7
	➤ PA system Panel	N.R.	N.R.	1
	➤ Batter backup	N.R.	N.R.	1
	➤ Building Floor plans	N.R.	N.R.	7
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	1

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/


Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Sunil Chawdhary

Name

Designation

D.O.

Designation