

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/ Banquet /2012/ 582 Dated: 21 / 02 /2012


FIRE SAFETY CERTIFICATE

Certified that the **M/s Celebration Banquet Hall** is comprised of basement, ground and two upper floors only at A-16/3, Wazir Pur Industrial Area, New Delhi-110052., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 10-02-2012 in presence of Mr. Dharam Vir Verma (Proprietor) of the Banquet Hall and that the building / premises is fit for occupancy Class-D (Assembly) with effect from 21 / 02 / 12.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....21 / 02 / 12.....at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to:
Mr. Dharam Vir Verma (Proprietor)
Celebration Banquet Hall at A-16/3,
Wazir Pur Industrial Area, New Delhi-52.



Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

So Sadih. (may)

May Kindly pursue letter no. nil dated 24/01/11 received from Sh. Dharam vir verma (Proprietor) regarding issue of NOC from fore safety point of view in r/o Celebration Banquet Hall at A-16/3, Wazir Pur Industrial Area, New Delhi-52. Premises was inspected by DO (MN) on 10/02/12 and observed that the building is comprised of basement, ground & two upper floors only having plot area of 450 sq. mtrs. Approx.

1. Name & address of the building : Celebration Banquet Hall at A-16/3, Wazir Pur Industrial Area, New Delhi-52.
2. Type of Occupancy : Assembly
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : F6/DFS/MS/BP/2011/43 dated 06/01/2012
6. Date of inspection : 10/02/2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
From the building side : Mr. Dharam Vir Verma (Proprietor)
9. Year of Construction : 19975 Old Building
10. Applicant's letter No. : Nil dated 05.08.2011

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06 mtrs	9 mtrs	M/R ✓
	• Gate width	5 mtr	5 mtr	M/R ✓
	• Width of internal road	Required	Provided As per section plan	M.R. ✓
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	3 stairs	Provided	M.R. ✓
	• Upper Floors	3 stairs	Provided	M.R. ✓
	• Basement	2 stairs	Provided	M.R. ✓
	b. Width of staircases			
	• Upper Floors	Two stair width 1.5 mtr & 3 rd stair width 3 feet	Provided	M.R. ✓
	• Basement	Two stair width 1.5 mtr & 3 feet	Provided	MR ✓
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	M.R. ✓
	• Pressurization	N.R	N.P.	Not applicable ✓
	d. No. of continuous staircases to terrace	Two stairs form ground to terrace		✓
	e. Width of Corridor	NR	N.P., halls only	MR ✓
	f. Door size	2 mtrs	Provided	MR ✓
3.	Compartmentation.			
	• Fire check door	Required	Provided	M.R. ✓
	• Sealing of electrical shafts	NR	NP	Not applicable ✓
	• Fire Rating of shaft door	NR	NP	Not applicable ✓
	• Water Curtain	NR	NP	Not applicable ✓
	• Fire Dampers	NR	NP	Not applicable ✓
4.	Smoke Management System.			

	<ul style="list-style-type: none"> Basements Upper floors 	Required	Provided	M.R. ✓
		Required	Provided	M.R. ✓
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	10	Provided	M/R ✓
	<ul style="list-style-type: none"> Types 	ABC	5 ABC, 5 CO ²	M.R. ✓
	<ul style="list-style-type: none"> IS marking 	ISI marked	ISI marked	M/R ✓
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	2	Provided	M/R ✓
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 mtr	M/R ✓
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	M/R ✓
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & heat	Provided	M.R. ✓
	<ul style="list-style-type: none"> Location of Main Panel 	Ground floor	Provided	M.R. ✓
	<ul style="list-style-type: none"> Location of Repeater Panel 	Ground floor	Provided	M.R. ✓
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Hooter's Location 	Required	Provided	M.R. ✓
8.	MOEFA	Required	Provided	M/R ✓
9.	Public Address System.	Required	Provided	M/R ✓
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Upper Floor 	Provided	Provided	M.R. ✓
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	M.R. ✓
11.	Internal Hydrants			

	<ul style="list-style-type: none"> • Size of riser/down-comer 	4 inch	Provided	M.R. ✓
	<ul style="list-style-type: none"> • Number of hydrants per floor 	2 nos on each floor	Provided	M.R. ✓
	<ul style="list-style-type: none"> • Hose Box 	2 nos. on each floor with two Hoses & branch	Provided	M.R. ✓
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	N.R.	N/P	Not applicable ✓
	<ul style="list-style-type: none"> • Hose Box 	N.R.	N/P	Not applicable ✓
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2280 LPM	Provided	M.R. ✓
	➤ Head of Main pump	70 mtr	Provided	M.R. ✓
	➤ Number of main pumps	2	Provided	M.R. ✓
	➤ Jockey Pump out put	Two jockey 180 LPM	Provided	M.R. ✓
	➤ Jockey pump head	70 mtr	Provided	M.R. ✓
	➤ Standby pump out put	2280 LPM	Provided	M.R. ✓
	➤ Standby pump Head	70 mtr	Provided	M.R. ✓
	➤ Auto Starting/Manual stopping	Required	Provided	M.R. ✓
	➤ Pump Hose Access	Required	Provided	M.R. ✓
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R. ✓
	➤ Head of the pump	40 mtr	Provided	M.R. ✓
	➤ Power supply	Required	Provided	M.R. ✓
	➤ Auto Starting of pump	Required	Provided	M.R. ✓

14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	50,000 ltrs	Provided	M.R. ✓
	➤ Draw -off connection	Required	Provided	M.R. ✓
	➤ Fire service inlet	Required	Provided	M.R. ✓
	➤ Access to tank	Required	Provided	M.R. ✓
	➤ Overhead Tank Capacity	20,000 lts	provided	M.R. ✓
15	Exit Signage.	<i>Required</i>	<i>Provided</i>	<i>M.R.</i>
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A	N.A.	Not applicable ✓
	• Pressurization of Lift lobby	N.A	N.A.	Not applicable ✓
	• Communication In lift Car	N.A.	N.A.	Not applicable ✓
	• Fireman's Grounding Switch	N.A	N.A.	Not applicable ✓
	• Lift Signage	N.A.	N.A.	Not applicable ✓
17.	Standby power supply	Required	Provided	M.R. ✓
18.	Refuge Area			
	➤ Total Area	N.R	N.R.	Not applicable ✓
	➤ Location	N/R	N.R.	Not applicable ✓
19.	Fire Control Room			
	➤ Detector System Panel	N.R	N.R.	Not applicable ✓
	➤ Flow Switch Panel	N.R	N.R.	Not applicable ✓
	➤ PA system Panel	N.R	N.R.	Not applicable ✓
	➤ Batter backup	N.R	N.R.	Not applicable ✓
	➤ Building Floor plans	N.R	N.R.	Not applicable ✓

20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable
-----	---	------	------	----------------

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....

Signature of the Inspection Officer *[Signature]* 14/2/12

Signature of the Inspection Officer

Name *SUNIL (HAWDARY)*

Name

Designation *D.O.*

Designation