

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI**


No. F6/MS/DFS/GH/2012/ 559

Dated: 17/02/12

FIRE SAFETY CERTIFICATE

Certified that the U.S.A. Guest House located at 9303/6, Multani Dhanda, Pahar Ganj, New Delhi comprised of basement (storage), ground floor (02 guest rooms + reception + lobby + 02 offices), 1st floor (06 guest rooms), 2nd floor (06 guest rooms) and 3rd floor (06 guest rooms) 4th floor (01 store room + kitchen for staff + 01 staff room) total 20 guest rooms was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/759 dated 18-03-2009. The premises was re-inspected by the officer concerned of this department on 07-02-2012 in the presence of Sh. Vishal Sehgal and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 20 guest rooms with effect from 17.02.2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 17/02/12 at New Delhi by.


CHIEF FIRE OFFICER
FOR DIRECTOR
DELHI FIRE SERVICE

de
men

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi – 110049
2. Shri Vishal Sehgal M/s U.S.A. Guest House located at 9303/6, Multani Dhanda, Pahar Ganj, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

old case

INSPECTION REPORT

1. Name & address of the building : U.S.A. Guest House, 9303/6 Multani Dhanda, Pahar Garj, N.D.
2. Type of Occupancy : Group A + Residential
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F.6/DFS/MS/GH/2009/759 Dated: 18/03/09
5. Fire Safety directives letter No : - N.A -
6. Date of inspection : 07-02-2012
7. Name of the Inspecting Officers : A.D.O. D.S. Yadav
8. Name and designation of officers from the building side : Sh. Vishal Sehgal (Owner)
9. Year of Construction : Prior to 2009
10. Applicant's letter No. : 3853/ Addl. C.P./Lic. (H) dated New Delhi the 16/01/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR <i>old case PSS Area</i>
1	Access to building			
	• Road width	<u>06 mtr</u>	<u>06 mtr</u>	<u>M.R</u>
	• Gate width	<u>- N.A -</u>	<u>- N.A -</u>	<u>—</u>
	• Width of internal road	<u>- N.A -</u>	<u>- N.A -</u>	<u>—</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>one</u>	<u>one</u>	<u>M.R</u>
	• Basements	<u>one</u>	<u>one</u>	<u>M.R</u>
	b. Width of staircases			
	• Upper Floors	<u>1.25 mtr</u>	<u>1.25 M to 1.30M</u>	<u>M.R</u>
	• Basements	<u>1.25 mtr</u>	<u>1.25 mtr</u>	<u>M.R</u>
	c. Protection of exits			
	• Fire check door	<u>N.A</u>	<u>N.A - separate entry/exit</u>	<u>N.A</u>
	• Pressurization	<u>- N.A -</u>	<u>- N.A -</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>one</u>	<u>one</u>	<u>M.R</u>
	g. Width of Corridor	<u>- N.A -</u>	<u>N.A</u>	<u>N.A</u>
	h. Door Size	<u>- N.A -</u>	<u>- N.A -</u>	<u>N.A</u>

contd. -

U.S.A. Guest House, 9303/6,
 Multani Dhanda, Paharganj,
 New Delhi.

old case

3	Compartmentation.	N.A		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	yes yes	M.R. M.R.
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	12 nos ISI marked	12 Nos CO ₂ Type w. CO ₂ Type yes	M.R. M.R. M.R.
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	yes 30 m 5 mm	yes yes yes	M.R. M.R. M.R.
7	Automatic fire detection and alarming system.	N.A		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	yes	yes	M.R.
9	Public Address System.	yes	yes	M.R.
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	yes	yes	M.R.

contd.:-

U.S.A. Guest House, 9303/6,
 Multani Dhandh, Pahar Ganj, New Delhi.

old case

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	— N.A —	— N.A —	—
		— N.A —	— N.A —	—
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	— N.A —		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	— N.A —		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	— N.A —		
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	— N.A —		

contd: —

U.S.A. Guest House, 9303/6,
Maltani Dhanda, Palwal, New Delhi.

old case

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	yes	yes	M.R
		yes	yes	M.R
		5000 litres	5000 litres	M.R
15	Exit Signage.	yes	yes	M.R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	- N.A -		
17	Standby power supply	yes	D.G. set	M.R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	- N.A -		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	- N.A -		
20	Special Fire Protection Systems for Protection of special Risks, if any:	- N.A -		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

contd:-


U.S.A. Guest House, 9303/6, Multani
Dhanda, Pahar Ganj, New Delhi

(5)

Signature of the Inspecting Officer

Name

Designation

~~DO (Central)~~ 
19/2/12

Signature of the Inspecting Officer

Name D. S. Yadav.

Designation Assistant Divisional
Officer (Central)


08-02-12